

**FCBWD**

**Ordinance 201101**

*FALCON COVE BEACH WD*

Falcon Cove Beach Domestic Water Supply District(FCBWD)

PWS ID# OR41-00045

The purpose of this Ordinance is to protect the health of the people served by this water system by preventing contaminants from flowing backwards into the water supply. To accomplish this, these rules are in compliance with OAR 333-061-0070 thru 333-061-0074. This includes installation, maintenance and testing of backflow prevention devices and assemblies; as well as other rules to report backflow data to the Oregon Health Authority (Department of Human Services) every year.

Actual or potential cross connections are prohibited. If a potential exists for a cross connection and this is necessary, the water system must be protected by an appropriate backflow prevention device or assembly. Most high hazards or health hazards are specified in the above listed Oregon Administrative Rules. They should be given the highest priority by this water system.

FCBWD has the right to refuse or terminate water service to any customer who allows an unprotected cross connection to exist and to any customer who denies access at all reasonable times to District personnel or its agents to enter upon the premises to which water is furnished for the purpose of inspection for compliance with this Ordinance.

FCBWD requires the installation and maintenance of a District approved cross-connection or backflow device at each service connection. Cross connection control devices are required to be tested annually by a licensed Backflow Device Tester. Installation and testing will be done by or arranged by FCBWD.

FCBWD will allow a reasonable time to achieve compliance with our rules, but should a backflow incident occur, FCBWD has the right to terminate service immediately and restore it only after compliance can be verified.

DATED this 2<sup>th</sup> day of Feb, 2011

*Joannet Caselle*  
President

ATTEST:

*Debra [Signature]*  
Secretary

RECEIVED  
JUL 22 2013

Cross Connection  
Drinking Water Program