

West Laurel Acres Water, Co

MANDATED BY 1-7-94 FEDERAL ACT ALL EXISTING SPRINKLER SYSTEMS MUST COMPLY WITH THIS ORDINANCE BY FEB.1,1996

THE PURPOSE OF THIS ORDINANCE, IN CONJUNCTION WITH THE UNIFORM PLUMBING CODE OF OREGON CROSS CONNECTIONS REGULATIONS IS TO PROTECT THE HEALTH OF THE WATER COMSUMER AND THE POTABILTY OF THE WATER IN THE DISTRIBUTION SYSTEM.

INSPECTION AND REGULATION OF ALL ACTUAL OR POTENTIAL CROSS CONNECTIONS BETWEEN POTABLE AND NON POTABLE SYSTEMS IS REQUIRED IN ORDER TO MIMIMIZE THE DANGER OF CONTAMINATION OF PUBLIC POTABLE WATER SUPPLY.

CONTROLLING AND PREVENTING CROSS CONNECTIONS IS ACCOMPLISHED BY EITHER REMOVING THE CROSS CONNECTION OR INSTALLING AN APPROVED BACKFLOW PREVENTION ASSEMBLY TO PROTECT THE PUBLIC POTABLE SUPPLY.

THE WEST LAUREL ACRES WATER COMMITTEE IS REQUIRED TO ELIMINATE OR CONTROL ALL CROSS CONNECTIONS THROUGHOUT THE SERVICE AREA OF 313 AVE. THEREFORE ANYONE WANTING TO USE A SPRINKLER SYSTEM FROM THE WEST LAUREL ACRES WATER IS REQUIRED BY LAW TO COMPLY WITH THESE REGULATONS. THE OWNER OF THE PROPERTY IN WHICH A CROSS CONNECTION OCCURS IS FULLY RESPONSIBLE FOR ALL DAMAGES INCURRED.

THE WEST LAUREL ACRES WATER COMMITTEE WILL ENFORCE THE PROVISIONS OF THIS ORDINANCE. ALL APPROVED STANDARDS SHALL BE APPROVED BY THE WEST LUAREL WATER COMMITTEE. ALL BACKFLOW PREVENTION ASSEMBLIES REQUIRED BY THIS ORDINANCE SHALL BE A MODEL APPROVED BY THE WASHINGTON COUNTY HEALTH AUTHORITIES.

ALL DEVISES ARE REQUIRED TO BE TESTED AT LEAST ONCE A YEAR COMPLETED TEST REPORTS SHALL BE RETURNED TO WEST LAUREL WATER COMMITTEE WITHIN 30 DAYS AFTER RECEIPT OF THE YEARLY TEST NOTIFATION. TEST AND INSPECTIONS MAY BE REQUIRED ON A MORE FREQUENT BASIS AT THE DISCRETION OF WASHINGTON COUNTY HEALTH AUTHRORITIES.

AUTHORIZED WEST LAUREL ACRES WATER COMMITTEE MEMBERS SHALL HAVE FREE ACCESS AT REASONABLE HOURS OF THE DAY TO ALL PARTS OF A PREMISE OR WITHIN BUILDINGS TO WHICH WATER IS SUPPLIED.

WATER SERVICE SHALL BE REFUSED OR TERMINATED TO ANY PREMISE FOR FAILURE TO ALLOW NECESSARY INSPECTIONS.

FAILURE OF THE OWNER TO COOPERATE IN THE INSTALLATION, MAINTENANCE, REPAIR, INSPECTION OR TESTING OF BACKFLOW PREVENTION ASSEMBLIES REQUIRED BY THIS FEDERAL ORDINANCE SHALL BE GROUNDS FOR SHUTTING OFF THE WATER SUPPLY.

ANY QUESTIONS? PLEASE CALL RICK WOODS 628-2562