



# Crescent Water Supply & Improvement District

Received  
March 13 2023  
Cross Connection

*P.O. Box 247  
136101 Hwy 97 N  
Crescent, OR 97733  
541-433-2989*

## **Cross Connection Control Program**

The District program will follow rules as described in:

- (A) Oregon Administrative Rules, Chapter 333-61-0070.
- (B) AWWA accepted procedure and practice in cross connection control manual.
- (C) The District will maintain and test the backflow after the meter for a fee, as that is our point of delivery.
- (D) USC 10<sup>th</sup> edition manual of cross connection control manual. The District will at no charge provide a cross connection inspection for each member. After the inspection the member will be informed as to the proper approved OSHD assembly required. Approved double check assembly after the meter is the minimum requirement that each member will have installed. Approved assemblies shall also be installed at all locations where a known or potential hazard exists. For those meters with an RP assembly at the meter, another approved assembly may be required at high points of hazard when the public uses water. Public needs are to be protected. After the meter backflow assembly, any additional required backflow assemblies are the complete responsibility of the member and will be tested per OSHD ORS 333-61-0070 (10). The test report for the additional assemblies will be sent to the District annually per OSHD ORS. If you have any questions regarding the above-mentioned rule, please plan to attend a board meeting.