

4100661

VALLEY VIEW WATER DISTRICT  
4571 SW HILLSIDE DRIVE  
PORTLAND OR 97221  
(503) 292-8526

VALLEY VIEW WATER DISTRICT  
RULES AND REGULATIONS  
DISTRICT CROSS CONNECTION AUTHORITY

Backflow preventers shall be installed as required by the Oregon Health Division. The installation, maintenance and tests shall conform to OAR 333-61-070, 071, and 072. Please refer to the District's complete Rules and Regulations.

September 18, 1996

RECEIVED  
MAR 05 1997  
FIELD SERVICES  
DRINKING WATER PROGRAM

## PLUMBING AND CROSS CONNECTIONS

All plumbing within the buildings served by Valley View Water District shall be so installed and all plumbing fixtures so constructed as to prevent pollution of water supply by back siphoning or cross connections. The District's Manager or other authorized representative shall have the right to check the premises of users for any such plumbing fixtures or cross-connections. Any plumbing fixtures or cross-connections which present the possibility of contamination or pollution to the water supply shall be removed or corrected within ten days after notice by the District to the responsible property owner. If corrections or removal of the deficiency is not completed within the time specified by the District, the water service connection to the property may be removed, and said service connection shall not be restored until such defects and hazards have been eliminated.

Neither cross-connections nor physical connections of any kind shall be made to any other water supply whether private or public without the written consent and approval of the Board and the written approval and consent of any public agency involved with the supply and use of domestic water.

All plumbing within the building site which is installed, repaired or remodeled by the owner or occupier of the premises to which water is furnished by the District will conform to all existing building and/or plumbing codes and regulations. When in the opinion of the Board, said plumbing fails to conform to required codes or regulations, the owner or occupier of the premises shall be given ten days notice and thereafter the District may remove any connection which it may have for servicing the property, and said connection shall not be restored until such defects have been corrected.

Backflow preventers shall be installed as required by the State Plumbing Code. The installation, maintenance, and tests shall conform to OAR-Chapter 333. When a backflow device is used, the device and necessary appurtenances shall be a type approved by the Oregon State Board of Health. The device shall be the property of the property owner, whether installed on public or private property.

The property owner shall be responsible for the proper installation, maintenance, and tests as required by the Oregon Administrative Rules as listed above.

The device shall be installed at a location approved by the Water District, underground, at or near the property line. Ready access shall be provided for inspection and meter reading.