

Enabling Authority

Received
Nov 17 2024
Cross Connection

Water System Name: Swisshome Village

PWS ID# 41-00854

Purpose:

The purpose of this Ordinance is to protect the health of the people served by this water system by preventing contaminants from flowing backwards into the water supply. To accomplish this, these rules are in compliance with Oregon Administrative Rules (OARS) 33-061-0070 through 333-061-0074

Requirements:

Actual or potential cross connections are prohibited. If a potential exists for a cross connection the water system must be protected by an appropriate backflow prevention device or assembly.

Enforcement:

The water system has the right to refuse or terminate water service to any customer who does not:

- Install a backflow device or assembly, when an actual or potential cross connection exists.
- Test the assembly at least annually and complete necessary repairs.

The water system reserves the right to require a backflow device at the customer's side of the water meter if access is not allowed to determine if a backflow device or assembly is necessary.

The water system will allow a reasonable time to achieve compliance with our rules, but should a backflow incident occur, the water system has the right to terminate service immediately and restore it only after compliance.

Additional:

A list of all high hazard connections and how they are protected from cross connection is attached to this enabling authority.

This enabling authority is approved and adopted and will remain in effect as of this date until such time as revised or eliminated.

Printed Name: Lonny S. Sayles Title: DRC

Signature: 

Date: 11/17/2024