

RECEIVED
FEB 04 2011
FIELD SERVICES
DRINKING WATER PROGRAM

SOUTH PRAIRIE WATER DISTRICT

ENABLING AUTHORITY

South Prairie Water District PWS ID# OR 41-00892

The purpose of this authority is to protect the health of the people served by this water system by preventing contaminants from flowing backward into the water supply. To accomplish this, these rules are in compliance with OAR 333-061-0070 thru 333-061-0074. This includes installation, maintenance and testing of backflow prevention devices and assemblies; as well as other rules to report backflow data to the Oregon Health Authority (Department of Human Service) every year.


Actual or potential cross connections are prohibited. If a potential exists for a cross connection and this is necessary, the water system must be protected by an appropriate backflow prevention device or assembly. Most high hazards or health hazards are specified in the above listed Oregon Administrative Rules. They should be given the highest priority by this water system.

South Prairie Water District has the right to refuse or terminate water service to any customer who who does not install a backflow device or assembly, when necessary, test at least annually and repair if necessary the backflow devices on the customer's property.

South Prairie Water District reserves the right to demand a backflow device at the customer's side of the meter if access is not allowed to determine if a backflow device or assembly is necessary.

South Prairie Water District will allow a reasonable time to achieve compliance with our rules, but should a backflow incident occur, the water system has the right to terminate service immediately and restore it only after compliance has occurred.

South Prairie Water District Board of Directors adopted this authority on
1/27/11 2011 and authorized the president of the district to sign it.



President, South Prairie Water District