

# **STONE WATER DISTRICT**

## **ENABLING AUTHORITY**

RECEIVED  
FEB 15 2011  
FIELD SERVICES  
DRINKING WATER PROGRAM

Tone Water District PWS ID# **OR 41-01035**

The purpose of this authority is to protect the health of the people served by this water system by preventing contaminants from flowing backward into the water supply. To accomplish this, these rules are in compliance with OAR 333-061-0070 thru 333-061-0074. This includes installation, maintenance and testing of backflow prevention devices and assemblies; as well as other rules to report backflow data to the Oregon Health Authority (Department of Human Service) every year.

Actual or potential cross connections are prohibited. If a potential exists for a cross connection and this is necessary, the water system must be protected by an appropriate backflow prevention device or assembly. Most high hazards or health hazards are specified in the above listed Oregon Administrative Rules. They should be given the highest priority by this water system.

Tone Water District has the right to refuse or terminate water service to any customer who who does not install a backflow device or assembly, when necessary, test at least annually and repair if necessary the backflow devices on the customer's property.

Tone Water District reserves the right to demand a backflow device at the customer's side of the meter if access is not allowed to determine if a backflow device or assembly is necessary.

Tone Water District will allow a reasonable time to achieve compliance with our rules, but should a backflow incident occur, the water system has the right to terminate service immediately and restore it only after compliance has occurred.

Tone Water District Board of Directors adopted this authority on  
2/7/ 2011 and authorized the president of the district to sign it.

  
\_\_\_\_\_

President, Tone Water District