

ATTN: Dewey Verall

**RAINBOW ROCK VILLAGE MOBILE HOME PARK
96465 COVERDELL ROAD
BROOKINGS, OREGON 97415**

PWS # 41-01062

CROSS CONNECTION POLICY

The purpose of this policy is to protect the water supply of Rainbow Rock Village Mobile Home Park from contamination or pollution from any cross connections; and to assure that approved backflow prevention assemblies are tested when put into service and at least on an annual basis thereafter. This policy is in compliance with Oregon Administrative Rule (OAR) 333-061-0070 and the Uniform Plumbing Code (UPC) as adopted by the State of Oregon.

The installation or maintenance of any unprotected cross connection which would endanger the water supply of Rainbow Rock Village Mobile Home Park is prohibited. Any such cross connection now existing or hereafter installed is hereby declared unlawful and shall be immediately protected or eliminated.

The control or elimination of cross connection and the criteria from determining degree of hazard and prescribing appropriate levels of protection shall be in accordance with the UPC and the OAR's.

Water service to any premise shall be contingent upon the tenant providing appropriate cross connection control if determined necessary. Determinations and enforcement shall be the responsibility of the park owner in conjunction with the certified water operator. Water service may be refused or terminated to any tenant where an unprotected cross connection may allow contamination or pollutants to backflow into the public drinking system.

Authorized employees of Rainbow Rock Village Mobile Home Park with proper identification, shall have free access at reasonable hours of the day, to all outside areas of a premise or building to which drinking water is supplied for the purpose of conducting hazard assessment surveys. Water service may be refused or terminated, or maximum backflow protection may be required, to the premise where access to perform surveys is denied, where unprotected cross connections are located, or in the event that installed assemblies are not tested and maintained as required by ... State and local regulations.

Before any water service is terminated, a "due process" of notifying the tenant and providing a reasonable time for compliance to be achieved will be observed according to the operating procedures of Rainbow Rock Village Mobile Home Park. However, in the event of an actual backflow incident which endangers the public health, water service may be terminated immediately and not be restored until the cross connection is either eliminated or adequately protected.

Adopted 3/1/03