

**CROSS-CONNECTION CONTROL PROGRAM
FOR
WELDON MOBILE HOME PARK LLC**

Weldon Mobile Home Park LLC, in the interest of preserving its water quality from pollution or contamination of any kind, adopts the following Cross-Connection Program. This program meets the requirements and procedures set by the Oregon State Health Division, Administrative Rule No. 333-61-070

When a potential contamination of the Weldon Mobile Home Park LLC water system exists, an inspection and evaluation of the premises shall be performed by an inspector authorized by Weldon Mobile Home Park LLC. In the event of an actual cross-connection or potential cross-connection, the user will install an approved backflow device, or eliminate the cross-connection hazard. The device or control used shall be in accordance with any manuals of standard practice, pertaining to cross-connection control, approved by the Department of Human Services, the City of Medford and any requirements set forth by the National Safe Drinking Water Act, PL 93-523, and all subsequent legislation.

The Weldon Mobile Home Park LLC shall regulate the location, installation and testing of any backflow device installed on its water system. The cost of any changes in the water system outside the customer's property, or between the meter and the cut-off or disconnection, shall be the responsibility of the Weldon Mobile Home Park LLC.

Written reports shall be the responsibility of the Weldon Mobile Home Park LLC in accordance with Department of Human Services, Administrative Rule 333-61-070. Copies of inspection, evaluation, and testing shall be maintained. The annual summary report shall be filed with the Department of Human Services.

Existing users with a potential or actual cross-connection shall be given 3 months from the date of notification to complete the installation of an approved backflow device. The user must notify the Weldon Mobile Home Park LLC after installation for testing of the device. Upon inspection and evaluation of any new service, should a backflow device be required, the approved device must be installed and tested before the users water service may be turned on.