



Bolder City Park
11423 Upper Applegate Rd.
Jacksonville, Or. 97530

Community Water System Ordinance 41-01154

State of Oregon - Uniform Plumbing Code Chapter 10. Cross Connection Control Manual - Accepted Procedure & Practice.

Inspection and regulation of all actual or potential cross connections between potable and non-potable systems is required in order to minimize the danger of contamination or pollution of the public potable water system.

Bolder City Park is required to eliminate or control all cross connections throughout it's service area. Therefore, anyone wanting or using water from Bolder City Park is required to comply with these regulations.

LeRoy Knott will enforce the provisions of this ordinance. All approved standards shall be approved by Bolder City Park and LeRoy Knott. All backflow prevention assemblies required by this ordinance shall be a model approved by the Pacific Northwest Section American Water Works Association, Inc.

Approved backflow prevention assemblies required by this ordinance shall be installed under the direction of LeRoy Knott and/or under the supervision of the Cross Connection Specialist/Inspector per Bolder City Park and D & D Plumbing Co. standards.

All RPBA's, RPDAs, DCVAs, DCDAs, and PVBA's are required to be tested at least annually and all Air Gaps installed in lieu of an approved backflow prevention assembly shall be inspected at least annually. Completed Test Reports shall be returned to Bolder City Park within 30 days after receipt of the yearly test notification. Tests and inspections may be required on a more frequent basis at the discretion of LeRoy Knott.

Authorized employees of Bolder City Park with proper identification shall have free access at reasonable hours of the day to all parts of a premise or within buildings to which water is supplied. Water service shall be refused or terminated to any premise for failure to allow necessary inspections.

Failure of the customer to cooperate in the installation, maintenance, repair, inspection or testing of backflow prevention assemblies required by this ordinance shall be grounds for termination of water service to the premise or the requirement for an Air Gap separation.

LeRoy C. Knott



Bolder City Park
11423 Upper Applegate Rd.
Jacksonville, Or. 97530

Master List of Facilities To Inspect

Pump Houses

- Well #1 - 1 Device
- Well #2 - 2 Devices

Schedule of Periodic Re-inspection

Scheduled for inspection by D & D Plumbing Co. of Medford, Or. annually or when applicable - above locations.

Cross Connection Staff & Work Responsibilities

LeRoy Knott
Retta Knott
Tim Knott

Staff to make visual inspection monthly. Staff has been trained to carefully take water samples for testing and preparations for taking samples for research lab.

LeRoy C. Knott