

Enabling Authority

Water System Name: Terrand Mobile Terrace

PWS ID# 41- 01157 Revised Date: March 5, 2025

Purpose

The purpose of this ordinance is to protect the health of the people served by this water system by preventing contaminants from flowing backwards into the water supply. To accomplish this, these rules are in compliance with Oregon Administrative Rules (OARs) 333-061-0070 through 333-061-0074.

Requirements

Actual or potential cross connections are prohibited. If a potential exists for a cross connection the water system must be protected by an appropriate backflow prevention device or assembly.

Any high hazards, as specified in the OARs will be given the highest priority, and protected with an approved air gap or reduced pressure backflow assembly.

Enforcement

The water system has the right to refuse or terminate water service to any customer who does not:

- Install a backflow device or assembly, when an actual or potential cross connection exists.
- Test the assembly at least annually and complete necessary repairs

The water system reserves the right to require a backflow device at the customer's side of the water meter if access is not allowed to determine if a backflow device or assembly is necessary.

The water system will allow a reasonable time to achieve compliance with our rules, but should a backflow incident occur, the water system has the right to terminate service immediately and restore it only after compliance.


Additional

A list of all high hazard connections and how they are protected from a cross connection is attached to this enabling authority.

This enabling authority is approved and adopted and will remain in effect as of this date until such time as revised or eliminated.

Printed Name: Derek M. Ray

Title: Authorized Representative

Signature: 

Date: March 5, 2025

Printed Name: _____

Title: _____

Signature: _____

Date: _____

ADDENDUM – Water Supply Cross-Connection

56

RE: 2648 NE 201st Avenue, #
Fairview, Oregon 97024


Cross-Connections or Physical Connections with Other Water Supplies or Systems: Neither cross-connections nor physical connections of any kind shall be made to any other water supply, whether public or private. Whenever cross-connections to other water supply into the Water Association-system is found or whenever any other condition is found which presents the possibility of contamination or pollution, the water supply to such premises and/or other premises from which cross-connection is made shall be discontinued immediately until the cross-connection is eliminated or the condition remedied. All costs of disconnection and reconnection shall be charged to the water user and shall be a lien upon the real property served by the Water Association. The method of enforcement shall be a suit in equity following the procedures for foreclosure of a mortgage. The Water Association may require any necessary and appropriate checking devices in domestic lines. These requirements will be strictly observed as a matter of public health, safety, and welfare, as required by the State of Oregon Plumbing Codes.

ACCEPTED AND AGREED TO THIS 5th DAY OF March 2025

Tenant

Tenant

Tenant


Derek M. Ray, Authorized Representative

Tenant

Tenant