

Enabling Authority

Received
Feb 21 2024
Cross Connection

Water System Name: Sandy Boulevard Mobile Villa

Water System PWS ID # 41- 01262 Revised Date: 03/07/2023

Purpose

The purpose of this ordinance is to protect the health of the people served by this water system by preventing contaminants from flowing backwards into the water supply. To accomplish this, these rules are in compliance with Oregon Administrative Rules (OARs) 333-061-0070 through 333-061-0074.

Requirements

Actual or potential cross connections are prohibited. If a potential exists for a cross connection the water system must be protected by an appropriate backflow prevention device or assembly.

Any high hazards, as specified in the OARs will be given the highest priority, and protected with an approved air gap or reduced pressure backflow assembly.

Enforcement

The water system has the right to refuse or terminate water service to any customer who does not:

- Install a backflow device or assembly, when an actual or potential cross connection exists.
- Test the assembly at least annually and complete necessary repairs

The water system reserves the right to require a backflow device at the customer's side of the water meter if access is not allowed to determine if a backflow device or assembly is necessary.

The water system will allow a reasonable time to achieve compliance with our rules, but should a backflow incident occur, the water system has the right to terminate service immediately and restore it only after compliance.


Additional

A list of all high hazard connections and how they are protected from a cross connection is attached to this enabling authority.

This enabling authority is approved and adopted and will remain in effect as of this date until such time as revised or eliminated.

Printed Name: Laura L Hallett

Title: Certified Operator

Signature: 

Date: 03/07/2023

Printed Name: _____

Title: _____

Signature: _____

Date: _____

Sandy Boulevard Mobile Billa

Physical address: 20140 NE Sandy Blvd, Fairview, OR 970224

Mailing Address: P.O. Box 57, Fairview, OR 97024

Phone 503-756-1103

ENABLING ORDINANCE FOR SMALL WATER SYSTEMS

1/19/2023

Water system name - Sandy Boulevard Mobile Villa

Water system PWS ID # 41-01262

Certified operator – Laura Hallett

Type water source – Ground water well

System has 113 units in a mobile home park

Systems Cross Connection Program:

System has 1 “high hazards”

System has 3 double check valves that are tested annually


All assembly’s passed for years 2022 and 2023

Contracted by Burton Backflow & Irrigation LLC

PO Box 1927, Fairview, OR 97024

503-618-1806

Signed Certified Operator,


Laura Hallett

Date 03/07/2023

Sandy Mobile Villa
Physical address: 20140 NE Sandy Blvd, Fairview, OR 970224
Mailing Address: P.O. Box 57, Fairview, OR 97024
Phone 503-756-1103

Water system name - Sandy Boulevard Mobile Villa Water system PWS ID # 41-01262

CROSS CONNECTION IN THE MOBILE HOME PARK AND HIGH HAZARDS


This system has only one high hazard, it is the swimming pool.
The out flow to the pool is above the water level, so no water can back flow.
All Three of the back flow preventers have passed testing in the year 2022 & 2023

Valve #1 is a double check connection to the pool refill.
Outflow is above water level.
Make is (Watts), Model (LF009M3QT) size ¾, serial # 332277, High hazard
Location, locked in the pool pump room
Valve passed back flow testing on 2/17/2022 and 2023

Valve #2 is a double check, connected to Rockwood water.
Make is (Apollo), Model (RPFL4A)
Location, locked in the pool pump room
Valve passed back flow test on 2/17/2022 & 2023

Valve #3 is a double check, connection to Rockwood water.
Make is (Watts), Model (757) size 3", serial # VC-3196
Location, In vault at 201st Entrance
Valve passed back flow test on 2/17/2022 & 2023

Signed Certified Operator:


Laura Hallett

Date 03/07/2023