

Enabling Authority

Received
Oct 14 2025
Cross Connection

Water System Name: WAPATO WOODRIDGE ASSOCIATION

PWS ID# 41- 01510 Revised Date: 10/14/25

Purpose

The purpose of this ordinance is to protect the health of the people served by this water system by preventing contaminants from flowing backwards into the water supply. To accomplish this, these rules are in compliance with Oregon Administrative Rules (OARs) 333-061-0070 through 333-061-0074.

Requirements

Actual or potential cross connections are prohibited. If a potential exists for a cross connection the water system must be protected by an appropriate backflow prevention device or assembly.

Any high hazards, as specified in the OARs will be given the highest priority, and protected with an approved air gap or reduced pressure backflow assembly.

Enforcement

The water system has the right to refuse or terminate water service to any customer who does not:

- Install a backflow device or assembly, when an actual or potential cross connection exists.
- Test the assembly at least annually and complete necessary repairs

The water system reserves the right to require a backflow device at the customer's side of the water meter if access is not allowed to determine if a backflow device or assembly is necessary.

The water system will allow a reasonable time to achieve compliance with our rules, but should a backflow incident occur, the water system has the right to terminate service immediately and restore it only after compliance.

Additional

A list of all high hazard connections and how they are protected from a cross connection is attached to this enabling authority.

This enabling authority is approved and adopted and will remain in effect as of this date until such time as revised or eliminated.

Printed Name: Dustin Chase Title: President
Signature: Dustin Chase Date: 10/13/2025

Printed Name: CARL M MELINA Title: SWSO
Signature: Carl Melina Date: 10/14/2025

Amendment to the Rules & Regulations of Wapato Moorage Association

Adopted 10/5/2025

22. WATER

In accordance with requirements of the Oregon Health Authority, Wapato Moorage Association may discontinue water service to any premises for failure to:

- a. Remove or eliminate an existing unprotected or potential cross connection;
- b. Install a required approved backflow prevention assembly;
- c. Maintain an approved backflow prevention assembly; or
- d. Conduct the required testing of an approved backflow prevention assembly.

- Dustin Chase, President
Dustin Chase, 10/13/2025

CARL M. MELINA OWSO

Carl Melina 10/14/2025