

Enabling Authority for Pelican Bay Heights Water System LLC  
PWS ID#: 41-05779

Approved for Water System: May 31, 2012

The purpose of this ordinance is to protect the health of the people served by this water system by preventing contaminants from flowing backwards into the water supply. To accomplish this, these rules are in compliance with OAR 333-061-0070 through 333-061-0074. This includes installation, maintenance and testing of backflow prevention devices and assemblies, as well as other rules to report backflow data to the Oregon Health Authority every year.

Actual or potential cross connections are prohibited. If a potential exists for a cross connection and this is necessary, the water system must be protected by an appropriate backflow prevention device or assembly. Most high hazards or health hazards are specified in the above listed Oregon Administrative Rules (see attached Exhibit A), there are currently no high hazard or health hazards within our system.

Pelican Bay Heights Water System LLC has the right to refuse or terminate water service to any customer who does not install a backflow device or assembly, when necessary, test at least annually and repair if necessary the backflow devices on the customer's property.

Pelican Bay Heights Water System LLC reserves the right to demand a backflow device at the customer's side of the water meter if access is not allowed to determine if a backflow device or assembly is necessary.

Pelican Bay Water System LLC will allow a reasonable time to achieve compliance with our rules, but should a backflow incident occur, the water system has the right to terminate service immediately and restore it only after compliance.

Attached Exhibit B provides our Master List of Facilities.

*Removed NAK*

## Exhibit A

### High hazards/Health hazards

Agricultural (e.g., farms, dairies)  
Beverage bottling plants  
Car washes  
Chemical plants  
Commercial laundries and dry cleaners  
Premises where both reclaimed and potable water are used  
Film processing plants  
Food processing plants  
Medical centers (e.g., hospitals, medical clinics, nursing homes, veterinary clinics, dental clinics, blood plasma centers)  
Premises with irrigation systems that use the water supplier's water with chemical additions (e.g., parks, playgrounds, golf courses, cemeteries, housing estates)  
Laboratories  
Metal plating industries  
Mortuaries  
Petroleum processing or storage plants  
Piers and docks  
Radioactive material processing plants and nuclear reactors  
Wastewater lift stations and pumping stations  
Wastewater treatment plants  
Premises with piping under pressure for conveying liquids other than potable water and the piping is installed in proximity to potable water piping  
Premises where the water supplier is denied access or restricted access for survey  
Premises where the water is being treated by the addition of chemical or other additives