

Redwood Terrace Assisted Living Water System Enabling Authority

Water System Name: Redwood Terrace Assisted Living

Water System PWS ID#: 95017

The purpose of this ordinance is to protect the health of the people served by this water system by preventing contaminants from flowing backwards into the water supply. To accomplish this, these rules are in compliance with OAR 333-061-0070 through 333-061-0074. This includes installation, maintenance and testing of backflow prevention devices and assemblies; as well as other rules to report backflow data to the Oregon Health Authority every year.

Actual or potential cross connections are prohibited. If a potential exists for a cross connection and this is necessary, the water system must be protected by an appropriate backflow prevention device or assembly. Most high hazards or health hazards are specified in the above listed Oregon Administrative Rules. They should be given the highest priority by this water system.

Redwood Terrace Assisted Living Water System has the right to refuse or terminate water service to any customer who does not install a backflow device or assembly, when necessary, test at least annually and repair, if necessary, the backflow devices on the customer's property.

Redwood Terrace Assisted Living Water System Name reserves the right to demand a backflow device at the customer's side of the water connection if access is not allowed to determine if a backflow device or assembly is necessary.

Redwood Terrace Assisted Living Water System Name will allow a reasonable time to achieve compliance with or rules, but should a backflow incident occur, the water system has the right to terminate service immediately and restore it only after compliance.

Signature: _____

Date: 10-1-2025