

Enabling Authority

Water System Name: Green Acres RV Park

Water System PWS ID # 41- 95168 Revised Date: 4/08/19

Purpose

The purpose of this ordinance is to protect the health of the people served by this water system by preventing contaminants from flowing backwards into the water supply. To accomplish this, these rules are in compliance with Oregon Administrative Rules (OARs) 333-061-0070 through 333-061-0074.

Requirements

Actual or potential cross connections are prohibited. If a potential exists for a cross connection the water system must be protected by an appropriate backflow prevention device or assembly.

Any high hazards, as specified in the OARs will be given the highest priority, and protected with an approved air gap or reduced pressure backflow assembly.

Enforcement

The water system has the right to refuse or terminate water service to any customer who does not:

- Install a backflow device or assembly, when an actual or potential cross connection exists.
- Test the assembly at least annually and complete necessary repairs

The water system reserves the right to require a backflow device at the customer's side of the water meter if access is not allowed to determine if a backflow device or assembly is necessary.

The water system will allow a reasonable time to achieve compliance with our rules, but should a backflow incident occur, the water system has the right to terminate service immediately and restore it only after compliance.

Additional

A list of all high hazard connections and how they are protected from a cross connection is attached to this enabling authority.

This enabling authority is approved and adopted and will remain in effect as of this date until such time as revised or eliminated.

Printed Name: MARY Beach Title: Manager

Signature: Mary Beach Date: 4/08/19

Printed Name: Vernon K Jewell Title: Maintenance

Signature: Vernon Jewell Date: 4/6 9/19



Drinking Water Program
Pendleton Office

- (34) No marijuana plants will be allowed to be visibly seen within any tenants lots or rv's. You will be evicted. There will be no tolerance for abusing this rule.
- (35) No vehicles shall be blocking the main roads within the park. Emergency vehicles must have a clear access to tenant emergencies.
- (36) No speeding here in the park..
- (37) No pets are allowed in the rec. room facilities, not even service animals. There are people who have allergies, and it is unsanitary.
- (38) Report any park problems to the manager or a park personnel.
- (39) If you have a problem with a neighbor, please try to work it out. If it is serious, then contact the sheriff's department. The man cannot fix any petty arguments.
- (40) No digging holes other than for fences and this must be approved ahead of time so that the underground utilities are not damaged.
- (41) Fences are not to be over the height of 4 feet unless there is a clear view through the fence/s. Park personnel must be able to see the condition of your lot.
- (42) Any violation of park standards of lot conditions may result in an eviction if the lot is not cleaned up. The health department is very strict about this rule.
- (43) No children are allowed to play in the pole barn area, other lots, main front lawn area, rec room facilities, around dumpsters or in flower beds here in the park.
- (44) If a tenant, his guest or children commit a crime here in the park, they can be given a 24 hour eviction.
- (45) No skates, scooters or bikes allowed in the rec room facilities.
- (46) No large pools or hot tubs/saunas allowed here in the park. You may have a small kids pool.
- (47) anyone caught pilfering through another tenants trash cans/sacks, will be evicted.
- (48) Any tenant caught allowing someone else to stay with them that have not been approved by management, could face an eviction.
- (49) Do not take any water from any of the rec room facilities. It is for the bathroom and laundry uses only..
- (50) Absolutely no dying your hair in bathrooms.
- (51) Please abide by any other rules posted anywhere in the park.
- (52) *No Flying any drones in park ever!*
- (53) All faucets connecting to your RV must have a backflow prevention attached to it. Tenant is responsible for all costs to buy and to have a backflow device installed, including any annual testing when required. Management reserves the right to discontinue water service to premises for failure to install an approved water backflow device or to conduct required testing of device.

If you wish to have garbage picked up, once a week. Cost shall be \$6.00 per garbage can, per month. Must buy your own 33 gallon garbage can with lid and garbage sacks to line inside of cans. If you are interested in this service, please notify management.

RECEIVED
APR 17 2019

Signed _____ Dated _____

OFFICE 1-541-481-2205
1-541-371-7097