

## Enabling Authority

Water System Name: \_\_\_\_\_ SILVER SPUR RV PARK \_\_\_\_\_

Water System PWS ID # 41- 95241 \_\_\_\_\_ Revised Date: \_\_\_\_\_ 10/20/2023 \_\_\_\_\_

### Purpose

The purpose of this ordinance is to protect the health of the people served by this water system by preventing contaminants from flowing backwards into the water supply. To accomplish this, these rules are following Oregon Administrative Rules (OARs) 333-061-0070 through 333-061-0074.

### Requirements

Due to the unique nature of an RV Park no cross connections will be allowed that could possibly cause water to flow backwards into the water system. All hose bibs at individual sites will have a backflow device installed. The main water system must be protected by an appropriate backflow prevention device or assembly. Any high hazards, as specified in the OARs will be given the highest priority and protected with an approved air gap or reduced pressure backflow assembly.

### Enforcement

The RV Park has the right to refuse or terminate water service to any customer who:


- Uses any potential equipment which could possibly cause a cross connection situation
- Removes a backflow device from the hose bib at rented site

The RV Park will allow a reasonable time to achieve compliance with our rules, but should a backflow incident occur, the water system has the right to terminate service immediately and restore it only after compliance.

### Additional

A list of all high hazard connections and how they are protected from a cross connection is attached to this enabling authority. This enabling authority is approved and adopted and will remain in effect as of this date until such time as revised or eliminated.

Printed Name: William Margne Title: General Manager

Signature:  Date: 10/20/2023

Printed Name: \_\_\_\_\_ Title: \_\_\_\_\_

Signature: \_\_\_\_\_ Date: \_\_\_\_\_