



January 9, 2020

Ed Hodges, PE  
Curran-McLeod, Inc.  
6655 S.W. Hampton St., Suite 210  
Portland, OR 97223

**Re: Falcon Cove Beach Water District (PWS #00045) – New Well L132105  
Curran-McLeod Project # 1530  
Conditional Approval (PR #77-2019). SRF SD# 19-242**

Dear Mr. Hodges:

Thank you for your submittal to the Oregon Health Authority's Drinking Water Services (DWS) of plan review information for the new well on behalf of the Falcon Cove Beach Water District.

On May 6, 2019, our office received a site map showing the location of a new well proposed for the District and a preliminary water well construction diagram. A plan review fee of \$825 and Land Use Compatibility Statement (LUCS) was received on May 6, 2019.

On January 7<sup>th</sup> - 8<sup>th</sup>, 2020 we received the plans showing how the well is to be connected to the system, revised lease agreement with OPRD indicating hazards will be prohibited within 100-ft of the well, approved waiver of the Geologic Hazard Overlay provisions issued by Clatsop County, and LUCS approved by Clatsop County. IOC and VOC results were also submitted.

SRF funds under SD# 19-242 are being used for the wellhouse, yard piping, residual disinfection system, and related appurtenances for which a Categorical Exclusion from further environmental review was granted on January 7, 2020.

The well is to be designated SRC-CA Well #1 (L132105) on its own entry point "C" (EP-C). Please ensure raw water sampling results indicate the sample location as "SRC-CA Well #1". Please ensure any treated water sampling representative of water entering the distribution system from this well is marked as having been taken at "EP-C Well #1".

**The project is approved provided the following conditions are met:**

- 1) Evidence of the applicable water rights required by the Water Resources Department is submitted – contact Nikki Hendricks with OWRD for further assistance with this.
- 2) Information that demonstrates how the water system meets OAR 333-061-0050(5)(e): “Provisions shall be made to alert the water supplier before the chlorine supply is exhausted.” This requirement can be satisfied by either installing a low-level chlorine alarm or by creating a written procedure to check the chlorine tank daily.
- 3) A raw water sample tap (prior to chlorine injection) is installed (both raw and treated water sample taps are needed);
- 4) The chlorine product being used demonstrates it meets NSF Standard 60;
- 5) Testing equipment is provided to determine the chlorine residual. The equipment must be a DPD-test kit or other EPA approved method of testing.
- 6) Test results for SOC, Uranium, Radium 226/228, Gross Alpha, and coliform bacteria (presence/absence) are submitted (VOC and IOC results from sampling completed 3/6/19 was submitted on 1/7/20). As required of the spring sources, annual raw water source sampling for coliform bacteria taken from a sample tap at the wellhead and prior to chlorine injection will be an on-going sampling requirement. Subsequent monitoring will depend upon the results of initial monitoring and will generally be as shown in table 1 below.

***Nikki Hendricks***  
Watermaster, Dist. 1  
Oregon Water Resources Department  
4000 Blimp Blvd. Suite 400  
Tillamook, OR 97141  
Phone: 503-815-1967  
Fax: 503-815-1968  
Email: [Nikki.M.Hendricks@oregon.gov](mailto:Nikki.M.Hendricks@oregon.gov)

IOC and VOC Test results from sampling completed 3/6/19 showed the following detections:

- Barium = 0.0341 mg/l (MCL = 2 mg/l)
- Iron = 0.066 mg/l (secondary standard = 0.3 mg/l)
- Magnesium = 14.3 mg/l
- Sodium = 32.1 mg/l (secondary standard = 20 mg/l)
- Fluoride = 0.11 mg/l (MCL = 10 mg/l)
- pH = 6.6 (secondary standard = 8.5. pH less than 7.0 is corrosive)

**Please note that approval for use of this well is not granted until a “Final Approval” letter has been issued.**

January 9, 2020

Table 1 – Initial monitoring				Year 2	Year 3
Year 1					
Sampling to be completed prior to Final Approval	Sample by the end of the first quarter of operation (after Final Approval)	2nd Quarter of Operation	3rd Quarter of operation		
Sample at the Source (SRC-CA)	Sample at the Entry Point (EP-C) to the distribution system served by the new source				
<ul style="list-style-type: none"> <li>Coliform</li> <li>Nitrate, Nitrite</li> <li>IOC, VOC, SOC</li> <li>Arsenic</li> <li>Radiological including uranium, gross alpha, and radium 226/228</li> </ul>	<ul style="list-style-type: none"> <li>Radiological</li> </ul>	<ul style="list-style-type: none"> <li>Radiological if detects</li> </ul>	<ul style="list-style-type: none"> <li>Radiological if detects</li> </ul>	Annual: <ul style="list-style-type: none"> <li>Nitrate</li> <li>VOC</li> <li>SOC</li> <li>Raw water coliform (pre-treatment)</li> </ul>	
Sampling at Customer Taps	Tap Sampling in the Distribution System (to assess impact of the new well on distribution system corrosion).				
<ul style="list-style-type: none"> <li>Lead and Copper</li> </ul>	<ul style="list-style-type: none"> <li>Sample at 10 Tier 1 sites (1<sup>st</sup> 6-months of operation)</li> </ul>		<ul style="list-style-type: none"> <li>Sample at 10 Tier 1 sites (second 6 months of operation)</li> </ul>	Reduction to 5 tap samples every 3 years is possible depending upon results	

Documentation and test results submitted to address the above-mentioned items should reference Plan Review #77-2019 and can be emailed to me at [evan.e.hofeld@state.or.us](mailto:evan.e.hofeld@state.or.us) or mailed to:

Attn: Evan Hofeld  
 OHA-Oregon Drinking Water Program  
 PO BOX 14450  
 Portland, OR 97293-0450

If you have any questions, please feel free to call me at 971-673-0419.

Sincerely,





Evan Hofeld, PE  
 Oregon Health Authority – Drinking Water Services


CC: Charles Dice, Falcon Cove Beach Water District  
 Annette Pampush, Tillamook County Environmental Health  
 Gail Henrikson, Clatsop County Community Development  
 Nikki Hendricks, Oregon Water Resources Department  
 Alice Beals, Oregon Parks and Recreation Department

### Project Description

The project includes drilling a new well to serve the District as shown below.



APPROXIMATE LOCATION OF NEW WELL  
LATITUDE: 45.78815' ±  
LONGITUDE: -123.964701' ±



**WELLHOUSE PLAN VIEW**  
SCALE 1" = 1'-0"

**WELLHOUSE ELEVATION VIEW**  
SCALE 1" = 1'-0"

**MATERIALS**

- ① SHED: RUBBERMAID MODEL 1967672 57"W X 77.2"L X 76.8H
- ② HYPOCHLORITE CHEMICAL TANK
- ③ HYPOCHLORITE PUMP
- ④ WATER LINES: 1 1/2" SCH 40 PVC PIPE AND FITTINGS
- ⑤ 1 1/2" WATER METER
- ⑥ VALVES: 1 1/2" BRASS GATE VALVES
- ⑦ PORTABLE HEATER (BY OWNER)
- ⑧ 4-TUBE FLUORESCENT LIGHT FIXTURE
- ⑨ 120 VAC RECEPTACLES (WIRING BY OWNER)
- ⑩ SUBMERSIBLE WELL LEVEL TRANSDUCER
- ⑪ WELL LEVEL INDICATOR
- ⑫ HOSE BIBB
- ⑬ NEMA 4X PLASTIC TELEMETRY J-BOX

**MATERIAL SPECIFICATION**

HYPOCHLORITE CHEMICAL FEED PUMP	0.2 – 3.0 GPD, 100 PSI (MAX), 5–100% FLOW RATE ADJUSTMENT, 25 FT SUCTION LIFT, 120 VAC, 60 HZ, POLYCARBONATE HOUSING, SANTOPRENE TUBING, WITH SUCTION AND DISCHARGE TUBING, CONNECTION NUTS, SUCTION STRAINER, AND INJECTION CHECK VALVE. STENNER PUMPS MODEL 45MHP2, OR EQUAL.
CHEMICAL DRUM	15 GALLON CROSS LINKED WHITE POLYETHYLENE CHEMICAL TANK WITH REMOVABLE FLAT LID. SUITABLE FOR 12% SODIUM HYPOCHLORITE SOLUTION STORAGE. NOMINAL DIMENSIONS: 14.5" DIA X 24" HIGH, NSF-61 LISTED
FLOW METER	1 1/2" THREADED CONNECTION WITH ADAPTERS AS NEEDED. FLOW RANGE 2–100 GPM, MAX CONTINUOUS FLOW 50 GPM, GPM MEASUREMENT UNITS, PULSE OUTPUT CONTACTOR 10 GALLONS PER PULSE, THERMOPLASTIC HOUSING, NSF-61 CERTIFICATION. NEPTUNE TECHNOLOGY GROUP T-10 FLOW METER WITH PULSE OUTPUT.

WELL LEVEL DISPLAY	1/8" DIN PANEL METER, 3.5 DIGIT DISPLAY 120 VAC POWER, 4–20 MA EXCITATION INPUT, 2 ALARM RELAY OUTPUTS. DISPLAY TO BE INSTALLED IN MINIMUM 6" X 6" NEMA 4 POLYCARBONATE BOX SUITABLE FOR WALL MOUNTING. OMEGA DP20-A1-A2, OR EQUAL
WELL PRESSURE TRANSDUCER	RANGE 0 – 250 FEET, +/-0.25 % ACCURACY, 316SS WETTED PART, 8–28 VDC EXCITATION, OUTPUT 4–20 MA, 2–WIRE, POLYURETHANE CABLE JACKET, WITH ANTI-SNAG CONE AND CABLE HANGER. MEAS KPS1 J20 OR EQUAL
WELL PUMP (EXISTING)	5 HP, 230 VOLT, 1-PHASE, 50 GPM



**Geologist Evaluation of the Well Report (adequately constructed into confined aquifer)**

The well log (CLAT 55068, Well ID# L132105) shows that the well had been drilled on January 2, 2019. Plans show the well has a 5 HP, 50-gpm submersible pump. The well house is equipped with equipment needed for sodium hypochlorite residual disinfectant treatment and related controls, meters, and valves.

The proposed site plan was sent to our geologist, Tom Pattee, on 5/9/19. Mr. Pattee evaluated the constructed well and provided the following comments on 5/21/19:

**CLAT 55068** WELL I.D. LABEL# L132105  
 START CARD # 1041604  
 ORIGINAL LOG #

STATE OF OREGON  
 WATER SUPPLY WELL REPORT  
 (as required by ORS 537.765 & OAR 690-205-0210)

1) LAND OWNER: Falcon Cove Beach Water District  
 2) TYPE OF WORK:  New Well  
 3) DRILL METHOD:  Rotary Air  
 4) PROPOSED USE:  Community  
 5) BORE HOLE CONSTRUCTION: Depth of Completed Well 173 ft.  
 6) CASING/LINER: Casing 166 ft, Liner 113 ft  
 7) PERFORATIONS/SCREENS: 1 screen, 4 perforations  
 8) WELL TESTS: Pump yield 21 gal/min, drawdown 160 ft

9) LOCATION OF WELL (legal description): CLAT 55068  
 10) STATIC WATER LEVEL: Existing Well / Pre-Alteration 141 ft  
 11) WELL LOG: Ground Elevation, Material, From, To  
 clay, brown w/boulders 0-2  
 clay, orange/brown 2-5  
 clay, brown w/silt 5-6  
 clay, orange/brown 6-12  
 clay, grey, sticky 12-18  
 sandstone, grey, med, soft 18-34  
 sandstone, brown, med 34-50  
 sandstone, grey, soft 50-53  
 sandstone, brown, med 53-63  
 sandstone, grey, med 63-76  
 sandstone, brown/orange 76-78  
 sandstone, grey, med 78-91  
 rock, black w/dark brown sandstone 91-94  
 sandstone, grey, med 94-151  
 rock, black/brown, broken w/grey sandstone seams 151-162  
 clay, grey 162-173

RECEIVED  
 FEB 10 2019  
 ONWARD

Dickerson Well Drilling, Inc.  
 (503)623-2664  
 Date Started: 12-27-2018, Completed: 01-02-2019

(unbonded) Water Well Constructor Certification  
 I certify that the work I performed on the construction, deepening, alteration, or abandonment of this well is in compliance with Oregon water supply well construction standards. Materials used and information reported above are true to the best of my knowledge and belief.  
 Signed: [Signature] License Number 1574 Date 01-30-2019

(bonded) Water Well Constructor Certification  
 I accept responsibility for the construction, deepening, alteration, or abandonment work performed on this well during the construction dates reported above. All work performed during this time is in compliance with Oregon water supply well construction standards. This report is true to the best of my knowledge and belief.  
 Signed: [Signature] License Number 1571 Date 01-30-2019

ORIGINAL - WATER RESOURCES DEPARTMENT  
 REPRODUCED TO THE WATER RESOURCES DEPARTMENT WITHIN 30 DAYS OF COMPLETION OF WORK. Form Version: 0.95

Comments: This well was drilled to a depth of 173 ft. The casing extends to a depth of 166 ft and the casing seal to a depth of 115 ft. The casing seal is completed 21 ft into a 57 ft thick sandstone layer that appears to be of low permeability and is assumed to act as confining layer. Sensitivity Analysis results suggest that the well construction is not sensitive to nearby land use practices.

**Nature of Aquifer Evaluation:**

Aquifer Nature:  Confined aquifer  Semi-confined aquifer  Unconfined aquifer  
 Comments: This well draws water from what is interpreted as a thin basalt layer within the surrounding sandstone. The water-bearing zone is directly overlain by 57 ft of sandstone that is assumed to be of low permeability and acts as a confining layer. The static water-level rose from where first encountered in the basalt at 151 ft below ground level to 141 ft below ground level. Sensitivity Analysis result suggest that the aquifer is not highly sensitive to local land use practices.