

June 7, 2023



800 NE Oregon Street, #640 Portland, OR 97232-2162 Phone: 971-201-9794

Fax: 971-673-0694 www.healthoregon.org/dwp

Christopher Brugato, PE Westech Engineering, Inc. Via email: cbrugato@westech-eng.com

Re: Tank and Pump Station (PR#70-2023) City of Aumsville (PWS ID#00065) Conditional Approval

Dear Chris:

Thank you for your submittal to the Oregon Health Authority's Drinking Water Services (DWS) of plan review information for the Water Storage Tank and Pump Station Improvements project for City of Aumsville. On May 25, our office received a plan review fee of \$3,300. On May 30, 2023, our office received plans and specifications. A geotechnical report was provided on June 6, 2023.

The project includes installation of a 1-million-gallon steel reservoir, pump station and associated piping and appurtenances to connect to the existing system. The location of the facility is next to the existing 1-million-gallon tank.

The plans are approved with the following conditions:

- The pump station must be located above the maximum anticipated 100-year (1 percent) flood level.
- Coliform bacteria sample result(s) must be submitted after disinfection of the reservoir is complete.

Until we receive verification that the conditions have been met and final approval has been issued, the facility is not approved for use. Upon completion of the project, the engineer must verify in writing that construction was completed according to the submitted plans. If substantial changes are made, a set of as-built drawings must be submitted. Documentation demonstrating how the above conditions were met should reference Plan

Review #70-2023 and can be emailed to me at Carrie.L.Gentry@oha.oregon.gov.

If you have any questions, please feel free to call me at (971) 201-9794. Sincerely,

Carrie Gentry, PE Regional Engineer Drinking Water Services

ec: Chantal Wikstrom, REHS, OHA/DWS