

March 13, 2026

Spencer Blizzard, EIT
AKS Engineering & Forestry, LLC
Via email: blizzards@aks-eng.com

**Re: Juno Hill Reservoir (PR#32-2026)
Bay City Water System (PWS ID#00079)
Conditional Approval**

Dear Spencer:

Thank you for your submittal to the Oregon Health Authority's Drinking Water Services (DWS) of plan review information for the Juno Hill reservoir project for Bay City Water System. On February 26, 2026, our office received plans, specifications and a geotechnical report. A plan review fee of \$3,300 was received on March 2, 2026. A land use compatibility statement was provided on March 12, 2026.

The project includes installation of a 500,000-gallon bolted steel reservoir adjacent to the existing Juno Hill Reservoir.

The plans are approved with the following conditions:

- All items in contact with potable water must meet NSF Standard 61 or equivalent.
- Disinfection of the reservoir prior to use must be accomplished according to AWWA Standard C652.

Until we receive verification that the conditions have been met and final approval has been issued, the facility is not approved for use. Upon completion of the project, the engineer must verify in writing that construction was completed according to the submitted plans. If substantial changes are made, a set of as-built drawings must be submitted. Documentation demonstrating how the above conditions were met should reference Plan Review #32-2026 and can be emailed to me at Carrie.L.Gentry@oha.oregon.gov.

If you have any questions, please feel free to call me at (971) 201-9794.

Sincerely,



Carrie Gentry, PE
Regional Engineer
OHA-Drinking Water Services
Carrie.L.Gentry@oha.oregon.gov

cc: Jaime Craig, REHS, Tillamook County Health Department
Nicole Alfafara, REHS, OHA/DWS
Brian Bettis, City of Bay City, bbettis@ci.bay-city.or.us