



PUBLIC HEALTH DIVISION
Drinking Water Services

Kate Brown, Governor

Oregon
Health
Authority

800 NE Oregon Street, #640
Portland, OR 97232-2162
Phone: 971-201-9794
Fax: 971-673-0694
www.healthoregon.org/dwp

April 13, 2022

Adam Odell, PE
Stantec
Via email, adam.odell@stantec.com

**Re: Sexton Pump Station Upgrade Phase 2 (PR#42-2022)
City of Beaverton (PWS ID#00081)
Conditional Approval**

Dear Mr. Odell:

Thank you for your submittal to the Oregon Health Authority's Drinking Water Services (DWS) of plan review information for the Sexton Pump Station Upgrades Phase 2 for City of Beaverton. On March 7, 2022, our office received a set of plans and specifications. A plan review fee of \$3,300 was received on March 15, 2022.

The project includes alteration of two existing pump stations at Sexton Mountain Meadows Park. The 550 Pump Station portion of the project will include a new building, new pumps, a PRV for reducing pressure from the 794 zone to the 550 zone, and hydro turbine equipment. The 794 Pump Station portion of the project will include upgrades to the roof of the structure, installation of chemical feed equipment (sodium hypochlorite) and new sampling equipment.

The plans are approved with the following condition:

- All items in contact with potable water must meet NSF Standard 61 or equivalent. Chemicals must meet NSF 60 or equivalent.

Until we receive verification that the condition has been met and final approval has been issued, the facility is not approved for use. Upon completion of the project, the engineer must verify in writing that construction was completed according to the submitted plans. If substantial changes are made, a set of as-built drawings must be submitted. Documentation demonstrating how the above conditions were met should reference Plan Review #42-2022 and can be emailed to me at Carrie.L.Gentry@dhsosha.state.or.us.

If you have any questions, please feel free to call me at (971) 201-9794.

Sincerely,

A handwritten signature in black ink, appearing to read 'C. Gentry', with a stylized flourish at the end.

Carrie Gentry, PE
Regional Engineer
Drinking Water Services

cc: Nicole Alfafara, OHA/DWS
Sheila Sahu, City of Beaverton