

Date

Mark Nelson, PE
Kennedy Jenks
Via email: marknelson@kennedyjenks.com

**Re: 209th Avenue Pump Station (PR#72-2025)
City of Beaverton (PWS ID#00081)
Conditional Approval**

Dear Mark:

Thank you for your submittal to the Oregon Health Authority's Drinking Water Services (DWS) of plan review information for the 209th Avenue Pump Station project for the City of Beaverton. On May 27, 2025, our office received a set of plans and specifications. A plan review fee of \$3,300 was received on May 29, 2025.

The project includes installation of a pump station and associated appurtenances. The pump station will include two booster pumps with space for a future pump.

The plans are approved with the following conditions:

- The pumps must be provided with a low-pressure cut-off switch on the suction side set at no less than 20 psi.
- The pump station must be located above the maximum anticipated 100-year (1 percent) flood level.
- All items in contact with potable water must meet NSF Standard 61 or equivalent.

Until we receive verification that the conditions have been met and final approval has been issued, the facility is not approved for use. Upon completion of the project, the engineer must verify in writing that construction was completed according to the submitted plans. If substantial changes are made, a set of as-built drawings must be submitted. Documentation demonstrating how the above conditions were met should reference Plan Review #72-2025 and can be emailed to me at Carrie.L.Gentry@oha.oregon.gov.

If you have any questions, please feel free to call me at (971) 201-9794.

Sincerely,



Carrie Gentry, PE
Regional Engineer
OHA-Drinking Water Services
Carrie.L.Gentry@oha.oregon.gov

cc: Nicole Alfafara, REHS, OHA/DWS
Tristan Wear, Project Engineer, City of Beaverton, twear@beavertonoregon.gov