

March 3, 2025

Mike Lees, PE
Anderson Perry & Associates
PO Box 1107
La Grande, Oregon 97850

**Re: New IMG Reservoir, Booster Pump Station, and Chlorination System,
Plan Review #182-2022, City of Boardman, PWS ID# 4100130
Final Approval**

Dear Mike:

Thank you for your submittal to the Oregon Health Authority's Drinking Water Services confirming the project was completed in accordance with the approved plans. The project consisted of constructing a new one-million-gallon storage reservoir, a booster pump station with on-site chlorine generation, and associated piping. **Final approval is granted for the project.**

If you have any questions or would like this in an alternate format, please feel free to call me at (541) 966-0900 or email at william.h.goss@oha.oregon.gov.

Sincerely,



William Goss, PE
Regional Engineer

c: Julie Wray, OHA – Drinking Water Services
Luis Campos, City of Boardman