

Health Authority

October 24, 2023

800 NE Oregon Street, Suite 640 Portland, OR 97232-2162 Phone: 971-673-0405

Fax: 503-673-0694 http://www.healthoregon.org/dws

Curt McLeod, PE (cjm@curran-mcleod.com)
Curran-McLeod, Inc.
6655 SW Hampton Street, Suite 210
Portland, OR 97223

Sent by email only

Re: Water Reservoir (PR#141-2023)

Boring Water District – WS # 00135)

Conditional Approval

Dear Curt:

Thank you for your submittal to the Oregon Health Authority's Drinking Water Services (DWS) of plan review information for the reservoir for Boring Water District. On October 20,2023, our office received plans, specifications, a land use and compatibility statement and a plan review fee of \$3,300.

The project includes the construction of a glass fused bolted steel reservoir with a capacity of 1 million gallons. The reservoir will be installed alongside a new 12" waterline on 287th Avenue.

The plans are approved with the following conditions:

• A silt stop must be provided at the outlet pipe.

Until we receive verification that the conditions have been met and final approval has been issued, the reservoir is not approved for use. Upon completion of the project, the engineer must verify in writing that construction was completed according to the submitted plans. If substantial changes are made, a set of as-built drawings must be submitted. Documentation demonstrating how the above conditions were met should reference Plan Review #141-2023 and can be emailed to me at keith.male@oha.oregon.gov.

If you have any questions, please feel free to email me at <u>keith.male@oha.oregon.gov</u> or call me at 503-939-1322.

Sincerely,

Keith Male, PE Regional Engineer

OHA-Drinking Water Services

CC:

Julie Wray, DWS

Chris Alexander, Title, Boring Water District: BoringWater.com