



PUBLIC HEALTH DIVISION
Center for Health Protection, Drinking Water Services

Tina Kotek, Governor

Oregon
Health
Authority

800 NE Oregon Street, Suite 640
Portland, OR 97232-2162
Phone: 971-673-0405
Fax: 503-673-0694
<http://www.healthoregon.org/dws>

October 24, 2023

Curt McLeod, PE (cjm@curran-mcleod.com)
Curran-McLeod, Inc.
6655 SW Hampton Street, Suite 210
Portland, OR 97223

Sent by email only

Re: Water Reservoir (PR#141-2023)
Boring Water District – WS # 00135)
Preliminary Approval

Dear Curt:

Thank you for your submittal to the Oregon Health Authority's Drinking Water Services (DWS) of plan review information for the reservoir for Boring Water District. On October 20, 2023, our office received plans, specifications, a land use and compatibility statement and a plan review fee of \$3,300.

The project includes the construction of a glass fused or epoxy coated bolted steel reservoir with a capacity of 1 million gallons. The reservoir will be installed alongside a new 12" waterline on 287th Avenue.

The project will be granted final approval subject to Boring Water District providing written verification that construction was completed according to the submitted plans. If substantial changes are made, a set of as-built drawings must be submitted. Documentation demonstrating how the above conditions were met should reference Plan Review #141-2023 and can be emailed to me at keith.male@oha.oregon.gov.

If you have any questions, please feel free to email me at keith.male@oha.oregon.gov or call me at 503-939-1322.

Sincerely,

Keith Male, PE
Regional Engineer
OHA-Drinking Water Services

CC:

Julie Wray, DWS

Chris Alexander, Title, Boring Water District: BoringWater@BoringWater.com