

December 16, 2025

Curt McLeod
Curran-McLeod, Inc.
6655 S.W. Hampton Street, Suite 210
Portland, Oregon 97223

**Re: S Walnut Street Waterline Extension (PR#52-2025)
Canby Utility (PWS ID#00157)
Conditional Approval**

Dear Curt:

Thank you for your submittal to the Oregon Health Authority's Drinking Water Services (DWS) of plan review information for the S Walnut Street Waterline Extension for Canby Utility. On December 2, 2025, our office received plans, a land use compatibility statement, and a plan review fee of \$3,300.

The project includes the installation of 12" and 18" ductile iron waterlines along S Walnut Street connecting to the existing distribution system of Canby Utility.

The plans are approved subject to the following conditions:

- Distribution piping must be carefully bedded and fully supported in material free from rocks.
- Air-relief valves, if needed, must be installed at high points where air can accumulate. The breather tube on air-relief valves must be extended above ground surface and provided with a screened, downward facing elbow.
- Pipe, pipe fittings, valves, and other appurtenances must be manufactured, installed and tested in conformance with the latest standards of the American Water Works Association, NSF International or other equivalent standards acceptable to the Authority.
- The design must allow for 20 psi to be maintained at all service meters.
- Disinfection of the waterline must be completed according to AWWA C651, including two samples collected at least 16 hours apart or as noted in the method.
- Any sewer and water line crossings must conform to [OAR 333-061-0050 \(9\)](#).

Until we receive verification that the conditions have been met and final approval has been issued, the waterline is not approved for use. Upon completion of the project, the engineer must verify in writing that construction was completed according to the submitted plans. If substantial changes are made, a set of as-built drawings must be submitted. Documentation demonstrating how the above conditions were met should reference Plan Review #52-2025 and can be emailed to me at keith.male@oha.oregon.gov.

If you have any questions, please feel free to email me at keith.male@oha.oregon.gov or call me at 503-939-1322.

Sincerely,



Keith Male, PE
Regional Engineer
Drinking Water Services

cc: Julie Wray, DWS
Sky Mason, PE, Curran-McLeod, Inc.