



15 June 2021

Daniel Willyard  
City of Cannon Beach  
PO Box 368  
Cannon Beach, Oregon 97110

*via email*

**Re: Pacific & W. Gogona Ave. Waterline (PR# 96-2021)  
City of Cannon Beach (WS ID# 00164)  
Conditional Approval**

Mr. Willyard:

Thank you for your submittal (through contractors) to the Oregon Health Authority's Drinking Water Services (DWS) of plan review information for the Pacific Street & W. Gogona Avenue Waterlines project for City of Cannon Beach. The project includes extending more than 650 feet of 8-inch HDPE & 4-12 -inch PVC waterline and associated appurtenances. On 8 June 2021 our office received plans, specifications, LUCS and a plan review fee of \$3,300.

**The plans are approved with the following condition(s)** {unless otherwise noted, rule references are from [OAR 333-061-0050...](#) }:

- The sewer and waterline crossings must conform to OAR (9)(c), as per Water Note 13 on Sheet 2. (9)(c)
- Disinfection of the waterline must be completed according to AWWA C651 (as noted on page 5, in OTAK's Water Pipe And Fittings for Cannon Beach Project, Section 261.4.05), which includes two bacteriological tests 16 hours apart. (10)(a)
- A minimum of 20 psi must be maintained at all service meters, by design. (8)(e)
- All items in contact with potable water must meet NSF Standard 61. 333-061-0087(5)

**Until we receive verification that the conditions have been met and final approval has been issued, the project is not approved for use.** Upon completion of the project, the engineer must verify in writing that construction was completed according to the submitted plans. If substantial changes are made, a set of as-built drawings must be submitted. Documentation demonstrating how the above conditions were met should reference Plan Review #96-2021 and can be emailed to me at the address above or mailed to:

Attn: [Pete Farrelly](#)  
OHA-Oregon Drinking Water Services  
PO Box 14450  
Portland, OR 97293-0450

If you have any questions, please feel free to contact me.

Sincerely,

A handwritten signature in black ink on a light blue background. The signature is cursive and appears to read "Pete Farrelly".

Pete Farrelly, PE  
Regional Engineer  
Drinking Water Services

cc: Kyle Ayers, PE, OTAK, Inc.  
808 SW Third Ave., Suite 800, Portland, OR 97201