



PUBLIC HEALTH DIVISION
Drinking Water Services

Tina Kotek, Governor

Oregon
Health
Authority

800 NE Oregon Street, #640
Portland, OR 97232-2162
Phone: 971-201-9794
Fax: 971-673-0694
www.healthoregon.org/dwp

September 29, 2023

Meagan Baker-Wilmes, AIA, LEED AP
Associate Principal
Soderstrom Architects
Via email: mbaker-wilmes@sdra.com

**Re: Chiloquin HS Gym Waterline (PR#120-2023)
Chiloquin Municipal Water Dept (PWS ID#00184)
Conditional Approval**

Dear Meagan:

Thank you for your submittal to the Oregon Health Authority's Drinking Water Services (DWS) of plan review information for the waterline project for the Chiloquin HS Gym within the Chiloquin Municipal Water Dept service area. On September 6, 2023, our office received plans, specifications, and a land use statement. A plan review fee of \$3,300 was received on September 7, 2023.

The project includes installation of C900 PVC waterline and associated appurtenances to serve the new gym.

The plans are approved with the following conditions:

- All items in contact with potable water must meet NSF Standard 61 or equivalent.
- The design must allow for 20 psi to be maintained at all service meters.
- After disinfection of the waterlines is completed, results from the coliform sampling must be provided to our office.

Until we receive verification that the conditions have been met and final approval has been issued, the facility is not approved for use. Upon completion of the project, the engineer must verify in writing that construction was completed according to the submitted plans. If substantial changes are made, a set of as-built drawings must be submitted. Documentation demonstrating how the above conditions were met should reference Plan

Review #120-2023 and can be emailed to me at Carrie.L.Gentry@oha.oregon.gov.

If you have any questions, please feel free to call me at (971) 201-9794.

Sincerely,

A handwritten signature in black ink, appearing to read 'C. Gentry', written in a cursive style.

Carrie Gentry, PE
Regional Engineer
Drinking Water Services

cc: Russ Kazmierczak, RG, OHA/DWS
Lance Lindow, REHS, Klamath County Environmental Health
Teresa Foreman, City Recorder, Chiloquin Municipal Water, chicityhall@gmail.com
Dennis Zullo, Klamath County School District, zullod@kcsd.k12.or.us