

December 16, 2014

Lisa Harrison, Finance Clerk
Beaver Water District
P.O. Box 306
Cloverdale, OR 97112

**Re: Beaver Water District Water System Master Plan (PWS #00199; PR #205-2014)
Concurrence of Findings**

The Oregon Drinking Water Services (DWS) received your submittal of the "Beaver Water District Water System Master Plan (May 2014)", and associated plan review fee on December 10, 2014. Upon review of the Plan, it appears the criteria listed in OAR 333-061-0060(5) have substantially been met.

The Beaver Water District Water System Master Plan represents a 20-year planning year period extending from 2013 through 2033. The plan includes a description and evaluation of the existing water system, future demand estimates, recommended system improvements, a Capital Improvement Plan (CIP), and a discussion of financing options. The CIP prioritizes the recommended improvement projects, and provides 2013 cost estimates.

Note that OAR 333-061-0060 contains plan submission and review requirements for major additions, or modifications to public water systems. Most of the Priority 1 and 2 projects presented in the Master Plan would require plan review. Construction plans must be submitted to and approved by DWS before construction begins.

If you have questions, please contact me at 971.673.0406, or via email at fred.n.kalish@state.or.us.

Sincerely,

Fred Kalish, P.E.
Regional Engineer

Cc: Rob Henry, HBH Engineering, 2316 Portland Rd, Suite H, Newberg, OR 97132
Annette Pampush, Tillamook County

