



August 15, 2024

Tony Favreau ([favreaugroup@msn.com](mailto:favreaugroup@msn.com))  
Favreau Engineering  
3750 Norwich Ave.  
Eugene, OR 97408

Sent by email only.

Re: Waterline Extension (PR#100-2024)  
City of Coburg – WS # 00200  
Conditional Approval

Dear Tony:

Thank you for your submittal to the Oregon Health Authority's Drinking Water Services (DWS) of plan review information for the Waterline Extension project for the City of Coburg. On July 15, 2024, our office received a set of plans and, on August 13, 2024, a plan review fee of \$3,300.

The project includes the installation of 12" C900 PVC waterline connecting two existing waterlines along the 15 Freeway near Van Duyn Road.

**The plans are approved with the following conditions:**

- A Land Use Compatibility Statement signed by Lane County must be submitted prior to the project receiving final approval.
- The design must allow for 20 psi to be maintained in the distribution system.
- PVC water lines must be provided with a tracer wire. The distance between tracer wire lead access locations must not be more than 1,000 feet.
- After disinfection of the waterlines is completed according to AWWA C651, results from the coliform sampling must be provided to OHA/DWS.

**Until we receive verification that the conditions have been met and final approval has been issued, the waterline is not approved for use.** Upon completion of the project, the engineer must verify in writing that construction was completed according to the submitted plans. If substantial changes are made, a set of as-built drawings must be submitted. Documentation demonstrating how the above conditions were met should reference Plan

Review #100-2024 and can be emailed to me at [keith.male@oha.oregon.gov](mailto:keith.male@oha.oregon.gov).

If you have any questions, please feel free to email me at [keith.male@oha.oregon.gov](mailto:keith.male@oha.oregon.gov) or call me at 503-939-1322.

Sincerely,

A handwritten signature in black ink that reads "Keith Male". The signature is written in a cursive, slightly slanted style.

Keith Male, PE  
Regional Engineer  
Drinking Water Services

cc: Julie Wray, DWS  
Amy Bleekman, REHS, OHA/DWS  
Nicholas Alviani, Lane County Health Department