

Health Authority

April 17, 2023

800 NE Oregon Street, #640 Portland, OR 97232-2162 Phone: 971-201-9794

Fax: 971-673-0694 www.healthoregon.org/dwp

Craig Massie, PE Project Manager Jacobs

Via email: Craig.Massie@jacobs.com

Re: Clay Street Reservoir Cover (PR#151-2022) City of Dallas (PWS ID#00248) Conditional Approval - Revised

Dear Craig:

Thank you for your submittal to the Oregon Health Authority's Drinking Water Services (DWS) of plan review information for the project name for water system. On August 24, 2022, our office received a set of plans. A plan review fee of \$3,300 was received on October 5, 2022. Revised plans were submitted on April 3, 2023.

The project includes installation of floating cover for the City's existing 3-million-gallon concrete reservoir. The existing reservoir cover was identified as a significant deficiency in the 2022 water system survey.

The plans are approved with the following conditions:

- All items in contact with potable water must meet NSF 61 or equivalent.
- The new covers must be watertight.
- Coliform bacteria sample result(s) must be submitted after disinfection of the reservoir is complete.

Until we receive verification that the conditions have been met and final approval has been issued, the facility is not approved for use. Upon completion of the project, the engineer must verify in writing that construction was completed according to the submitted plans. If substantial changes are made, a set of as-built drawings must be submitted. Documentation demonstrating how the above conditions were met should reference Plan

Review #151-2022 and can be emailed to me at Carrie.L.Gentry@oha.oregon.gov.

If you have any questions, please feel free to call me at (971) 201-9794. Sincerely,

Carrie Gentry, PE Regional Engineer Drinking Water Services

ec: Michelle Byrd, REHS, OHA/DWS
Tom Gilson, City of Dallas, Engineering Services Supervisor
Gary Marks, City of Dallas, Public Works Director