

September 4, 2013

Terry Owings  
City of Depoe Bay  
P.O. Box 8  
Depoe Bay, Oregon 97341

RE: Hwy 101 Access Improvements at MP 126.82  
Waterline Extension at Lillian Lane (PR #2013-118)  
City of Depoe Bay (PWS #OR4100254)  
*Conditional Approval*

Dear Mr. Owings,

Thank you for providing documents via Reece & Associates, Inc. for the waterline extension project at Lillian Lane for plan review. The Oregon Health Authority (OHA) Drinking Water Services (DWS) received the improvement plans and the \$600 plan review fee. At this time, DWS grants *conditional approval*.

Until we receive verification that the conditions have been met and the project is granted *final approval*, the project is not approved for use. The project will be granted *final approval* subject to Depoe Bay's (or its designated representative) written verification that the following *conditions* have been met:

1. Disinfection procedures for valves, water mains, and service connections shall be accomplished according to AWWA standards C651 through C654 (OAR 333-061-0050(10)(c)).
2. The tracer wire shall be No. 18 AWG (minimum) solid copper with blue colored insulation (OAR 333-061-0050(8)(k)). Tracer wire is called out for the sewers, but not the waterline, so please insure tracer wire is placed with waterline also.

*Waterline Extension at Lillian Lane (Hwy 101, MP 126.82)*  
City of Depoe Bay (PWS OR4100254; PR 2013-118)  
September 4, 2013

3. The points where the waterline crosses under the storm sewer, the storm sewer must be supported and backfilled to prevent settling (OAR333-061-0050(9)(c)(C)).

The clearance between the waterline and the storm sewer crossing at the inlet/catch basin at STA 2+59.76 is unclear. I recommend at least a one foot clearance between the two lines.

Please provide verification of the above conditions and any as-builts for changes to the design in writing and/or photographs via email to [rebecca.a.templin@state.or.us](mailto:rebecca.a.templin@state.or.us) or by conventional mail to our Springfield office.

If you have questions, please feel free to contact me at (541) 726-2587 x29 or email at the address above.

Sincerely,



Rebecca Templin, P.E.  
Regional Engineer, OHA Drinking Water Services

cc: Plan Review, DWS Portland  
Daniel Hough, DWS Springfield  
David J. Reece, Reece & Associates, Inc., 321 First Ave. E, Suite 3A,  
Albany, Oregon 97321