

10 May 2016

Brady Weidner
City of Depoe Bay
PO Box 8
Depoe Bay, Oregon 97341

**RE: Waterline Replacement, SW Coast Ave (PR #2016-64)
Depoe Bay (PWS OR4100254)
Conditional Approval**

Dear Mr. Weidner:

Thank you for submitting plans for *plan review* via Century West Engineering (CWE) for waterline replacement and service connections along SW Coast Avenue in Depoe Bay, Oregon. Oregon Health Authority Drinking Water Services (DWS) received a fee of \$3,300 along with plans and specifications for the project. DWS at this time grants the project *conditional approval*.

The project will be granted final approval subject to Depoe Bay (or its designated representative) providing written verification that the project was completed per plans and met OAR 333-061-0050 Construction Standards such as those described below.

1. Adequate blocking is provided where appropriate (e.g. Station 7+24).
2. Nonconductive water pipe is traced with electrically conductive wire, or other approved conductor, for locating the pipe when the pipeline is underground. The wire is No. 18 AWG (minimum) solid copper with blue colored insulation. Ends of wire are accessible in water meter boxes, valve boxes, or casings. The distance between tracer wire access locations is not more than 1,000 feet. Joints or splices in wire are waterproof.
3. Waterline running approximately parallel to sewer line within 5 feet horizontally is at least 18 inches higher elevation than sewer, unless explanation is provided as to why this is acceptable and noting mitigative measures where appropriate. Resolution of this condition may be needed between Stations: 3+02 to 3+67, 4+76 to 5+13, 5+34 to 6+65, and 10+21 to 10+90.

*Waterline Replacement, SW Coast Ave (PR #2016-)
City of Depoe Bay (PWS OR4100254)
Conditional Approval*

10 May 2016

If you have any questions, you are welcome to contact me at (541) 726-2587 extension 57 or via email at james.r.macpherson@state.or.us.

Sincerely,



James "Jay" MacPherson, Ph.D., P.E.
Region 2 Plan Review Coordinator
OHA Drinking Water Services

cc: Plan Review, DWS Portland
Tia Skerbeck, DWS Portland
Ron Weigel, CWE