



January 25, 2024

Dane Maben, EI
Anderson Perry & Associates
P.O. Box 1107
La Grande, Oregon 97850

**Re: Transmission Lines – Phase 2 & Reservoir, Plan Review #3-2024, City of Echo,
PWS ID #4100270
Preliminary Approval**

Dear Dane:

Thank you for your submittal of plan review information to the Oregon Health Authority's Drinking Water Services (DWS). On January 8, 2024, electronic copies of the plans, specifications, Land Use Compatibility Statement, and the review fee of \$825 were received. On January 12, 2024, a printed copy of the project drawings was received. The project consists of constructing a 500,000-gallon welded steel reservoir, related piping, and appurtenances. **The plans have been reviewed and preliminary approval is granted for the project.**

I have the following comments:

1. Notes on Sheet R-C04 refer to inlet and outlet piping details on Sheet R-C05, however the details appear on Sheet R-C07.
2. Notes in the internal piping outlet detail on Sheet R-C07 refers to Sheet R-C02 for continuation of the piping, however the continuation appears on Sheet R-C04.
3. I note that the foundation design will be done by the contractor.

Upon completion of the project, please verify in writing that the construction was completed according to the submitted plans. If substantial changes are made, a set of record (as-built) drawings must be submitted. Until it is verified that the project meets the construction standards in OAR 333-061-0050 and Final Approval is granted for the project, the new facilities are not approved for use.

If you have any questions or would like this in an alternate format, please feel free to call me at (541) 966-0900 or email at william.h.goss@oha.oregon.gov .

Sincerely,

A handwritten signature in blue ink that reads "William Goss" with a stylized flourish at the end.

William Goss, PE
Regional Engineer

c: Julie Wray, OHA–DWS, Portland, OR
David Slaght, City of Echo (pdf copy only)
Scott Morris, City of Echo (pdf copy only)