



PUBLIC HEALTH DIVISION  
Drinking Water Services

Kate Brown, Governor

Oregon  
**Health**  
Authority

800 NE Oregon Street, #640  
Portland, OR 97232-2162  
Phone: 971-201-9794  
Fax: 971-673-0694  
[www.healthoregon.org/dwp](http://www.healthoregon.org/dwp)

November 19, 2021

Buck Smith, PE  
PBS Engineering & Environmental  
Via email

**Re: Eagle Ridge at Currin Creek Phase 1 (PR#165-2021)  
City of Estacada (PWS ID#00279)  
Conditional Approval**

Dear Buck:

Thank you for your submittal to the Oregon Health Authority's Drinking Water Services (DWS) of plan review information for the Eagle Ridge at Currin Creek Phase 1 subdivision in the City of Estacada. On October 20, 2021, our office received a set of plans, land use compatibility statement and a plan review fee of \$3,300.

The project includes installation of 8" and 12" C900 waterlines and associated appurtenances for the new subdivision.

**The plans are approved with the following conditions:**

- All items in contact with potable water must meet NSF Standard 61 or equivalent.
- The design must allow for 20 psi to be maintained at all service meters.
- The distance between tracer wire lead access locations must not be more than 1,000 feet.
- Disinfection of the waterline must be completed according to AWWA C651. Results from the coliform sampling must be provided to our office.

**Until we receive verification that the conditions have been met and final approval has been issued, the facility is not approved for use.** Upon completion of the project, the engineer must verify in writing that construction was completed according to the submitted plans. If substantial changes are made, a set of as-built drawings must be submitted. Documentation demonstrating how the above conditions were met should reference Plan

Review #165-2021 and can be emailed to me at [Carrie.L.Gentry@dhsoha.state.or.us](mailto:Carrie.L.Gentry@dhsoha.state.or.us) or mailed to:

Attn: Carrie Gentry  
OHA-Oregon Drinking Water Services  
PO Box 14450  
Portland, OR 97293-0450

If you have any questions, please feel free to call me at (971) 201-9794.

Sincerely,

A handwritten signature in black ink, appearing to read 'Carrie Gentry', with a stylized flourish at the end.

Carrie Gentry, PE  
Regional Engineer  
Drinking Water Services

cc: Don DeRosia, Public Works Director, City of Estacada, [derosia@cityofestacada.org](mailto:derosia@cityofestacada.org)