



PUBLIC HEALTH DIVISION
Drinking Water Services

Kate Brown, Governor

Oregon
Health
Authority

800 NE Oregon Street, #640
Portland, OR 97232-2162
Phone: 971-201-9794
Fax: 971-673-0694
www.healthoregon.org/dwp

December 20, 2021

John Christiansen, PE, CWRE
AKS Engineering & Forestry LLC
Via email

**Re: River Mill Road RV Park Waterline (PR#203-2021)
City of Estacada (PWS ID#00279)
Conditional Approval**

Dear Mr. Christiansen:

Thank you for your submittal to the Oregon Health Authority's Drinking Water Services (DWS) of plan review information for the River Mill Road RV Park waterline project in the City of Estacada. On November 24, 2021, our office received a set of plans, land use compatibility statement and a plan review fee of \$3,300.

The project includes installation of 8" C900 PVC waterlines and associated appurtenances for the River Mill Road RV Park.

The plans are approved with the following conditions:

- All items in contact with potable water must meet NSF Standard 61 or equivalent.
- The design must allow for 20 psi to be maintained at all service meters.
- Disinfection of the waterline must be completed according to AWWA C651. Results from the coliform sampling must be provided to our office.

Until we receive verification that the conditions have been met and final approval has been issued, the facility is not approved for use. Upon completion of the project, the engineer must verify in writing that construction was completed according to the submitted plans. If substantial changes are made, a set of as-built drawings must be submitted. Documentation demonstrating how the above conditions were met should reference Plan Review #203-2021 and can be emailed to me at Carrie.L.Gentry@dhsosha.state.or.us or mailed to:

Attn: Carrie Gentry
OHA-Oregon Drinking Water Services
PO Box 14450
Portland, OR 97293-0450

If you have any questions, please feel free to call me at (971) 201-9794.

Sincerely,

A handwritten signature in black ink, appearing to read "Carrie Gentry". The signature is fluid and cursive, with the first name "Carrie" being more prominent than the last name "Gentry".

Carrie Gentry, PE
Regional Engineer
Drinking Water Services