

October 17, 2024

Ray Moore
All County Surveyors & Planners, Inc.
PO Box 955
Sandy, OR 97055

Re: Currin Creek Estates No. 3 Waterlines (PR#124-2024)
City of Estacada (PWS ID#00279)
Conditional Approval

Dear Ray:

Thank you for your submittal to the Oregon Health Authority's Drinking Water Services (DWS) of plan review information for the Currin Creek Estates No. 3 Waterlines for the City of Estacada. On June 10, 2024, our office received signed land use and compatibility statement, a set of plans, conditions of approval and, on October 17, 2024, a plan review fee of \$3,300.

The project includes the installation of 8" and 12" C900 PVC waterlines in the Currin Creek Estates subdivision of the City of Estacada.

The plans are approved subject to the following conditions:

- The design must allow for 20 psi to be maintained at all service meters.
- The distance between tracer wire lead access locations must not be more than 1,000 feet along nonmetallic pipelines.
- After disinfection of the waterlines is completed according to AWWA C651, results from the coliform sampling must be provided to OHA/DWS.

Until we receive verification that the conditions have been met and final approval has been issued, the waterlines are not approved for use. Upon completion of the project, the engineer must verify in writing that construction was completed according to the submitted plans. If substantial changes are made, a set of as-built drawings must be submitted. Documentation demonstrating how the above conditions were met should reference Plan Review #124-2024 and can be emailed to me at keith.male@oha.oregon.gov.

If you have any questions, please feel free to email me at keith.male@oha.oregon.gov or call me at 503-939-1322.

Sincerely,



Keith Male, PE
Regional Engineer
Drinking Water Services

cc: Julie Wray, DWS