

Tina Kotek, Governor

December 9, 2024

Curt McLeod, P.E. [[cjm@curran-mcleod.com](mailto:cjm@curran-mcleod.com)]  
Curran-McLeod, Inc.  
6655 S.W. Hampton Street, Suite 210  
Portland, Oregon 97223

*Sent by email only.*

Re: **Master Plan Approval (PR#157-2024)**  
**City of Estacada (PWS ID#00279)**

Dear Curt:


Thank you for your submittal to the Oregon Health Authority's Drinking Water Services (DWS) of plan review information for the Water System Master Plan for the City of Estacada. On December 2, 2024, our office received a copy of the City of Estacada Water System Master Plan Update. A plan review fee of \$4,125 was also received.

The Master Plan represents a 20-year planning horizon out to the year 2045. The plan includes system goals and description, future demand estimates, engineering evaluation, evaluations of options to meet future demand, financing, and list of recommended projects and cost estimates. A seismic risk assessment and mitigation plan is required and was included. Upon review of the Master Plan, it appears the elements required in Oregon Administrative Rules (OAR) 333-061-0060(5) have been addressed.

Please note that OAR 333-061-0060 contains plan submission and review requirements for all major water system additions or modifications. Construction plans and specifications must be submitted to and approved by DWS before construction begins.

If you have any questions, please feel free to call me at 503-939-1322 or email me at [keith.male@oha.oregon.gov](mailto:keith.male@oha.oregon.gov).

Sincerely,



Keith Male, PE  
Regional Engineer  
Drinking Water Services

cc: Julie Wray, DWS  
Chris Lewis, City of Estacada

