



PUBLIC HEALTH DIVISION
Center for Health Protection, Drinking Water Services

Tina Kotek, Governor

Oregon
Health
Authority

800 NE Oregon Street, Suite 640
Portland, OR 97232-2162

Phone: 971-673-0405

Fax: 503-673-0694

<http://www.healthoregon.org/dws>

January 23, 2024

Steve Roper (ropers@aks-eng.com)
AKS ENGINEERING & FORESTRY, LLC
12965 SW Herman Road, Suite 100
Tualatin, OR 97062

Sent by email only.

**Re: Faraday Hills Subdivision Waterline Extension Phase 6 (PR#6-2024)
City of Estacada (PWS #00279)
Conditional Approval**

Dear Steve:

Thank you for your submittal to the Oregon Health Authority's Drinking Water Services (DWS) of plan review information for the Faraday Hills Subdivision Waterline Extension Phase 6 for the City of Estacada. On January 10, 2024, our office received city council findings and conditions, a land use compatibility statement, transmittal submittal, sanitary sewer construction plans, water construction plans, and on January 23, 2024, a plan review fee of \$3,300.

The project includes the installation of new 8" C900 PVC waterlines and AWWA C110 or C153 ductile iron fittings in a new development in the City of Estacada. This development is part of the Faraday Hills Subdivision.

The plans are approved with the following conditions:

- After disinfection of the waterlines is completed according to AWWA C651, results from the coliform sampling must be provided to OHA/DWS.

Until we receive verification that the conditions have been met and final approval has been issued, the waterlines are not approved for use. Upon completion of the project, the engineer must verify in writing that construction was completed according to the submitted plans. If substantial changes are made, a set of as-built drawings must be submitted. Documentation demonstrating how the above conditions were met should reference Plan Review #6-2024 and can be emailed to me at keith.male@oha.oregon.gov.

If you have any questions, please feel free to call me at 503-939-1322 or email me at keith.male@oha.oregon.gov.

Sincerely,

A handwritten signature in black ink that reads "Keith Male". The signature is written in a cursive, flowing style.

Keith Male, PE
Regional Engineer
Drinking Water Services

cc: Julie Wray, DWS
Chris Lewis, City of Estacada