

June 13, 2024



800 NE Oregon Street, #640 Portland, OR 97232-2162 Phone: 971-201-9794

Fax: 971-673-0694 www.healthoregon.org/dwp

Joseph Payne, PE Director of Project Development Puttman Infrastructure, Inc. Via email: joseph.payne@puttman.com

**Re:** Storage Expansion Project (PR#98-2023)

South Coast Water Company (PWS ID#00302)

Final Approval

## Joseph

On June 4, 2024, our office received confirmation that the above project was completed according to the plans submitted and conditions set forth in the September 11, 2023 conditional approval letter. Coliform sample results were provided on June 11, 2024.

Final approval is issued at this time, and the facility is approved for use. As a reminder, if the water system exceeds 110% of the 32 gpm demand flow that the 2012 tracer study is based on, a new tracer study is required.

If you have any questions, please feel free to call me at (971) 201-9794.

Sincerely,

Carrie Gentry, PE Regional Engineer

**Drinking Water Services** 

cc: Amy Bleekman, REHS, OHA/DWS