

June 10th, 2025

Katamarina Wright
Glide Water Association
PO Box 384
Glide, OR 97443

sent by email only

Re: **Master Plan Approval (PR#28-2025)**
Glide Water Association (PWS ID#00326)
Concurrence

Dear Katamarina Wright:


Thank you for your submittal to the Oregon Health Authority's Drinking Water Services (DWS) of plan review information for the Water System Master Plan for the Glide Water Association. On May 15, 2025, I received a copy of the 2024 Glide Water Association Water Master Plan. A plan review fee of \$4,125 was also received.

The Master Plan represents a 20-year planning horizon out to the year 2044. The plan includes system goals and description, future demand estimates, engineering evaluation, evaluations of options to meet future demand, financing, and list of recommended projects and cost estimates. A seismic risk assessment and mitigation plan is required and was included as part of this master plan. Upon review of the Master Plan, it appears the elements required in Oregon Administrative Rules (OAR) 333-061-0060(5) have been addressed.

Please note that OAR 333-061-0060 contains plan submission and review requirements for all major water system additions or modifications. Construction plans and specifications must be submitted to and approved by DWS before construction begins.

If you have any questions, please feel free to call me at 541-231-9077.

Sincerely,

A handwritten signature in black ink that reads "Zach Golik". The signature is written in a cursive, flowing style.

Zach Golik, Regional Engineer
OHA-Drinking Water Services