

PUBLIC HEALTH DIVISION
Drinking Water Services
Kate Brown, Governor

Oregon
Health
Authority

444 A Street
Springfield, OR 97477
Ph. (541) 726-2587
Fax (541) 726-2596
<http://healthoregon.org/dwp>

3 April 2019

Michael Bollweg
City of Gold Hill
PO Box 308
Gold Hill, Oregon 97525

COPY

RE: Treatment Plant Improvements (PR #2016-64)
City of Gold Hill (PWS OR4100333)
Final Approval

Dear Mr. Bollweg:

Thank you for confirming completion of treatment plant improvements at the City of Gold Hill, Oregon via Civil West Engineering Services, Inc. (Civil West). Oregon Health Authority Drinking Water Services (DWS) received as-built plan drawings for the repair of corrosion in the settling basin, filter media replacement, air scour addition, and control system improvements. DWS grants the project *final approval*.

If you have any questions, you are welcome to contact me at (541) 726-2587 extension 57 or via email at james.r.macpherson@state.or.us.

Sincerely,

James "Jay" MacPherson, Ph.D., P.E.
Region 2 Plan Review Coordinator
OHA Drinking Water Services

cc: Plan Review, DWS Portland
Manny Ramos and Jim Parmenter, Civil West
Russ Kazmierczak, DWS Springfield
Susan Baker, Jackson County

"Assisting People to Become Independent, Healthy, and Safe"
An Equal Opportunity Employer