

2 July 2020

Mike Bollweg  
Southern Oregon Water Technology  
PO Box 308  
Gold Hill, OR 97525

**RE: Seismic Risk Assessment and Mitigation Plan (PR #2020-21)**  
**Gold Hill, City of (PWS OR4100333)**  
***Concurrence***

Dear Mr. Bollweg:

Thank you for submitting a seismic risk assessment and mitigation plan (SRAMP) for *plan review* via Civil West Engineering Services, Inc. (Civil West) for the City of Gold Hill. Oregon Health Authority Drinking Water Services (DWS) received a review fee of \$825 on 18 February 2020 along with an updated version of the SRAMP on 24 June 2020. DWS concurs with the SRAMP.

The SRAMP meets Oregon Administrative Rules (OAR) 333-061-0060(5)(a)(J) in that it:

- Identifies critical facilities capable of supplying key community needs, including fire suppression, health and emergency response, and community drinking water supply points;
- Identifies and evaluates the likelihood and consequences of seismic failures for each critical facility; and
- Encompasses up to a 50-year planning horizon and includes recommendations for minimizing water loss from each critical facility, capital improvements, or further study or analysis.

Please note that OAR 333-061-0060 contains plan submission and review requirements for all major water system additions or modifications. Construction

*Seismic Risk Assessment and Mitigation Plan (PR #2020-21)  
Gold Hill (PWS OR4100333)  
Concurrence*

2 July 2020

plans and specifications must be submitted to and approved by DWS before construction begins.

Thank you for the thorough preparation of the Gold Hill SRAMP. If you have any questions, you are welcome to contact me at (541) 726-2587 extension 57 or via email at [james.r.macpherson@state.or.us](mailto:james.r.macpherson@state.or.us).

Sincerely,



James "Jay" MacPherson, Ph.D., P.E.  
Region 2 Plan Review Coordinator  
OHA Drinking Water Services

ec: Plan Review, DWS Portland  
Manny Ramos, Civil West  
David Kung, Civil West  
Susan Baker, Jackson County