



Oregon

Theodore R. Kulongoski., Governor

Department of Human Services
Public Health Division
Drinking Water Program
P.O. Box 14450
Portland, OR 97293-0450

August 17, 2010

Bob Duddles, Superintendent
Crystal Springs Water District (PWS ID #00386)
P.O. Box 186
Odell, OR 97044-0186

(971) 673-0459
(971) 673-0694 – FAX
(971) 673-0372 - TTY-Nonvoice

**Replacement of On-site Chlorination Generation Unit, Plan Review # 2010-131, Crystal Springs Water District, PWS 41 00386
Final Approval**

Dear Mr. Duddles:

Thank you for your submittal to the Drinking Water Program of information related to the replacement of the on-site sodium hypochlorination generation equipment at the Crystal Springs Water District. Information on make and model number of the unit, as well as National Sanitation Foundation (NSF) Standard 61 certification was received by the DWP. The project involves replacing the existing sodium hypochlorite on-site generation system with an MCT-12 ClorTec unit. The project is approved without conditions.

If you have any questions or concerns, or would like this in an alternate format, please contact me at (971) 673-0459, or james.b.nusrala@state.or.us. Your cooperation is appreciated.

Sincerely,

James Nusrala, P.E.
Regional Engineer
Drinking Water Program
www.oregon.gov/DHS/ph/dwp