



# Oregon

Theodore R. Kulongoski, Governor

Department of Human Services  
Public Health Division  
800 NE Oregon Street  
Portland, OR 97232-2162

March 16, 2010

(971) 673-0406  
(971) 673-0694 - FAX  
(971) 673-0372 - TTY-Nonvoice

Wade Seaborne  
Seaborn Engineering  
PO Box 314  
Mosier OR 97040

**RE: Crystal Springs Water, PWS #4100386, Pine Crest PUD Waterlines,  
PR# 19-2010  
Conditional Approval**

Dear Mr. Seaborn;

We have received plans, LUCs and Fee for the above project. We have completed our review there are some items for your attention:

1. NSF Certification for all materials in contact with the water, OAR 333-061-0087.
2. Air release valves must be provided for at high spots, OAR 333-061-0050(8)(i).

When the project is complete, the engineer must submit a statement that the project was constructed in accordance with the approved plans or if modifications have been made a set of as-built plans must be submitted.

If you would like this information in an alternate format, please contact Marsha Fox at (971) 673-0408.

Sincerely,

Tom Charbonneau, PE  
Department of Human Services,  
Drinking Water Program

cc: James Nusrala, Department of Human Services  
Hood River County Health Department

*"Assisting People to Become Independent, Healthy and Safe"*  
An Equal Opportunity Employer

