



PUBLIC HEALTH DIVISION  
Drinking Water Services

Kate Brown, Governor

Oregon  
**Health**  
Authority

800 NE Oregon Street, #640  
Portland, OR 97232-2162  
Phone: 971-673-0459  
Fax: 971-673-0694  
[www.healthoregon.org/DWP](http://www.healthoregon.org/DWP)

September 4, 2018

Thomas Ferrell, PE  
Pace Engineers, Inc.  
5000 Meadows Road  
Suite 345  
Lake Oswego, OR 97035-2232

**Re: Pine Crest Development Phase II Water System Improvements (PR#97-2016)  
Crystal Springs Water District (PWS ID#00386)  
Final Approval**

Dear Mr. Ferrell:

Thank you for your submittal to the Oregon Health Authority's Drinking Water Services (DWS) of supplemental plan review information for the Pine Crest Development Phase II project for Crystal Springs Water District. On August 14, 2018, our office received information documenting that conditions outlined in the July 12, 2016 conditional approval letter have been met. Additionally, the pump station and reservoir facilities were inspected as part of the April 5, 2018 water system survey. Earlier, our office received a set of plans, specifications, land use compatibility statement, geotechnical report and a plan review fee of \$4,125. **Final approval is issued for the project and the facilities are approved for use.**

The project includes a new pump station and PRV building, a new 80,000 gallon concrete reservoir, distribution piping and associated appurtenances.

If you have any questions, please feel free to contact me at (971) 673-0459 or [james.b.nusrala@state.or.us](mailto:james.b.nusrala@state.or.us). Thank you for your cooperation in completing the project.

Sincerely,

James Nusrala, PE  
Regional Engineer  
Drinking Water Services

cc: Fredrick Schatz, Crystal Springs Water District, P.O. Box 186, Odell, OR 97044  
Ian Stromquist, REHS, Hood River County Environmental Health