

Heal Coregon Leading

August 22, 2023

800 NE Oregon Street, #640 Portland, OR 97232-2162 Phone: 971-201-9794

Fax: 971-673-0694 www.healthoregon.org/dwp

Gordon Munro, PE Senior Civil Project Manager Tetra Tech Via email: Gordon.Munro@tetratech.com

Re: 1 Million Gallon Reservoir (PR#79-2023) City of Lafayette (PWS ID#00452) Conditional Approval

## Dear Gordon:

Thank you for your submittal to the Oregon Health Authority's Drinking Water Services (DWS) of plan review information for the reservoir project for City of Lafayette. On June 16, 2023, our office received plans and specs for the project. A plan review fee of \$3,300 was received on June 23, 2023.

The project includes installation of one-million-gallon steel reservoir, associated piping to connect to the distribution system and upsized transmission piping.

The plans are approved with the following conditions:

- The outlet end of the drain/overflow must be fitted with angle-flap valve or equivalent protection.
- The roof access hatch must have curbing around the opening and a lockable watertight cover that overlaps the curbing.
- Coliform bacteria sample result(s) must be submitted after disinfection of the reservoir is complete.

Until we receive verification that the conditions have been met and final approval has been issued, the facility is not approved for use. Upon completion of the project, the engineer must verify in writing that construction was completed according to the submitted plans. If substantial changes are made, a set of as-built drawings must be submitted.

Documentation demonstrating how the above conditions were met should reference Plan Review #79-2023 and can be emailed to me at Carrie.L.Gentry@oha.oregon.gov.

If you have any questions, please feel free to call me at (971) 201-9794. Sincerely,

Carrie Gentry, PE Regional Engineer

CAS

**Drinking Water Services** 

cc: Nicole Alfafara, REHS, OHA/DWS

Greggory Robinson, Public Works Supervisor, pw@ci.lafayette.or.us