

July 23rd, 2025

Kevin Sims
City of Lakeview
525 N. Street
Lakeview, OR 97630

sent by email only


Re: Well 10 and Well 11 (PR#49-2024)
City of Lakeview (PWS ID#00464)
Final Approval

Dear Kevin Sims:

On June 11th, 2025, the Oregon Health Authority Drinking Water Services (DWS) received confirmation that the above project was completed according to the plans submitted and conditions set forth in the April 24th, 2024, conditional approval letter and as-builts provided by Anderson Perry on April 7, 2025.

This verification completes the plan review requirements. Final approval is issued at this time, and the facility is approved for use. Please refer to the City's public water system online data profile for monitoring and reporting requirements associated with "Well #10" and "Well #11". Please note that the as-built evaluation of the wells indicated the new wells are utilizing an unconfined aquifer and care should be taken to avoid sanitary hazards being placed in the well setbacks. If you have any questions, please feel free to call me at 541-231-9077.

Sincerely,



Zach Golik, PE
Regional Engineer
OHA-Drinking Water Services

CC: Russ Kazmierczak, DWS Springfield