

September 17, 2024

Neil Pietrok, PE
Civil Engineer
Bradford Consulting Engineers, Inc.
Via email: neilpietrok@bradfordengineers.com

**Re: Imperial River Company Waterline (PR#111-2024)
City of Maupin (PWS ID#00510)
Conditional Approval**

Dear Name:

Thank you for your submittal to the Oregon Health Authority's Drinking Water Services (DWS) of plan review information for the Imperial River Company waterline project in the City of Maupin. On August 21, 2024, our office received items plans and a plan review fee of \$3,300.

The project includes installation of about 620 feet of 8" C900 PVC and associated appurtenances.

The plans are approved with the following conditions:

- All items in contact with potable water must meet NSF Standard 61 or equivalent.
- The design must allow for 20 psi to be maintained at all service meters.
- Disinfection of the waterline must be completed according to AWWA C651. Results from the coliform sampling must be provided to our office.

Until we receive verification that the conditions have been met and final approval has been issued, the facility is not approved for use. Upon completion of the project, the engineer must verify in writing that construction was completed according to the submitted plans. If substantial changes are made, a set of as-built drawings must be submitted. Documentation demonstrating how the above conditions were met should reference Plan Review #111-2024 and can be emailed to me at Carrie.L.Gentry@oha.oregon.gov.

If you have any questions, please feel free to call me at (971) 201-9794.

Sincerely,



Carrie Gentry, PE
Regional Engineer
OHA-Drinking Water Services
Carrie.L.Gentry@oha.oregon.gov

cc: Jessie Elias, REHS, North Central Public Health District
Chantal Wikstrom, REHS, OHA/DWS
Kirk Shields, Public Works Foreman, City of Maupin, kshields@cityofmaupin.org
Rob Miles, Imperial River Company, rm@deschutesriver.com