

Tina Kotek, Governor

March 11, 2025

Russ Foltz  
Mill City Water Department  
PO Box 256  
Mill City, OR 97360

*sent by email only*

**Re: SW Evergreen Waterline (PR#29-2025)  
Mill City Water Department (PWS ID#00520)  
Conditional Approval**

Dear Russ Foltz:

Thank you for your submittal to the Oregon Health Authority's Drinking Water Services (DWS) of plan review information for the SW Evergreen Waterline for Mill City Water Department. On February 26<sup>th</sup>, 2025, DWS received engineered drawings and a plan review fee of \$3,300.

The waterline project includes the installation of approximately 584 linear feet of 12-inch ductile iron pipe in the right-of-way of SW Evergreen Street. The work will be performed in the incorporated community of Mill City, Oregon.

The plans are approved subject to the following conditions:


*Disinfection-*

- Following construction or installation of new facilities and repairs to existing facilities, those portions of the facilities which will be in contact with water delivered to users must be cleaned and flushed with potable water and disinfected according to AWWA Standards C651 through C654 before they are placed into service. Disinfection must be by chlorine unless another disinfectant can be demonstrated to be equally effective. Reference OAR 333-061-0050(10).

**Until we receive verification that the conditions have been met and final approval has been issued, the SW Evergreen Waterline is not approved for use.** For waterline projects, note that engineers must inspect/be prepared to sign off before burying lines. Upon completion of the project, the engineer must verify in writing that construction was completed according to the submitted plans. If substantial changes are made, a set of as-built drawings must be submitted. Documentation demonstrating how the above conditions were met should reference Plan Review #29-2025 and can be emailed to me at zachariah.cunningham-golik@oha.oregon.gov.

If you have any questions, please feel free to call me at 541-231-9077.

Sincerely,



Zach Golik, PE  
Regional Engineer  
Drinking Water Services

CC: Stephen Kirkley, Linn County Environmental Health